

Отчет о суточных параметрах
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Гашкова ул, д. 26/3 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 00137628

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2023	70.37	46.69	23.68	120.77	121.77	-0.82	118.10	120.52	-2.03	-2.42	7.00	6.00	2.797	24.0	0.0	
02.03.2023	73.99	50.67	23.32	149.68	151.03	-0.90	146.05	149.22	-2.15	-3.17	7.00	6.00	3.407	24.0	0.0	
03.03.2023	79.26	54.68	24.58	162.72	163.96	-0.76	158.28	161.67	-2.12	-3.39	7.00	6.00	3.895	24.0	0.0	
04.03.2023	73.11	48.38	24.73	124.73	125.74	-0.81	121.78	124.34	-2.08	-2.56	7.00	6.00	3.010	24.0	0.0	
05.03.2023	70.87	45.34	25.53	101.77	102.58	-0.79	99.47	101.56	-2.08	-2.09	7.00	6.00	2.542	24.0	0.0	
06.03.2023	70.48	45.32	25.16	106.55	107.43	-0.82	104.18	106.39	-2.10	-2.21	7.00	6.00	2.619	24.0	0.0	
07.03.2023	70.40	45.59	24.81	107.18	108.07	-0.83	104.78	107.01	-2.11	-2.23	7.00	6.00	2.597	24.0	0.0	
08.03.2023	70.05	46.10	23.95	116.96	118.02	-0.90	114.42	116.84	-2.09	-2.42	7.00	6.00	2.741	24.0	0.0	
09.03.2023	70.15	44.84	25.31	99.55	100.41	-0.86	97.35	99.49	-2.17	-2.14	7.00	6.00	2.465	24.0	0.0	
10.03.2023	69.32	42.60	26.72	83.49	84.21	-0.86	81.73	83.51	-2.15	-1.78	7.00	6.00	2.183	24.0	0.0	
11.03.2023	69.32	45.04	24.28	109.11	110.11	-0.91	106.75	109.08	-2.16	-2.33	7.00	6.00	2.591	24.0	0.0	
12.03.2023	70.23	45.81	24.42	106.88	107.84	-0.89	104.54	106.77	-2.11	-2.23	7.00	6.00	2.554	24.0	0.0	
13.03.2023	68.54	41.68	26.86	79.79	80.49	-0.87	78.11	79.81	-2.15	-1.70	7.00	6.00	2.096	24.0	0.0	
14.03.2023	65.30	44.82	20.48	124.35	125.79	-1.15	121.96	124.60	-2.14	-2.64	7.00	6.00	2.492	24.0	0.0	
15.03.2023	69.49	44.03	25.46	93.98	94.79	-0.86	91.91	93.93	-2.17	-2.02	7.00	6.00	2.339	24.0	0.0	
16.03.2023	68.79	42.30	26.49	79.67	80.38	-0.89	78.00	79.70	-2.16	-1.70	7.00	6.00	2.067	24.0	0.0	
17.03.2023	67.31	40.59	26.72	70.96	71.61	-0.91	69.51	71.09	-2.25	-1.58	7.00	6.00	1.856	24.0	0.0	
18.03.2023	68.36	43.86	24.50	94.55	95.39	-0.88	92.56	94.53	-2.11	-1.97	7.00	6.00	2.267	24.0	0.0	
19.03.2023	69.10	45.41	23.69	102.38	103.34	-0.93	100.20	102.32	-2.09	-2.12	7.00	6.00	2.373	24.0	0.0	
20.03.2023	68.13	43.89	24.24	89.69	90.51	-0.91	87.83	89.70	-2.11	-1.87	7.00	6.00	2.126	24.0	0.0	
21.03.2023	68.02	43.04	24.98	85.22	85.59	-0.43	83.45	84.85	-1.66	-1.40	7.00	6.00	2.084	24.0	0.0	
22.03.2023	65.93	42.27	23.66	89.74	90.70	-1.06	87.96	89.96	-2.25	-2.00	7.00	6.00	2.082	24.0	0.0	
23.03.2023	66.65	43.29	23.36	94.74	95.75	-1.06	92.84	94.92	-2.22	-2.08	7.00	6.00	2.169	24.0	0.0	
24.03.2023	64.68	40.52	24.16	73.63	74.43	-1.08	72.22	73.84	-2.22	-1.62	7.00	6.00	1.743	24.0	0.0	
25.03.2023	64.22	39.35	24.87	71.81	72.59	-1.08	70.47	72.06	-2.23	-1.59	7.00	6.00	1.752	24.0	0.0	
26.03.2023	64.42	39.84	24.58	70.54	71.31	-1.09	69.21	70.75	-2.20	-1.54	7.00	6.00	1.701	24.0	0.0	
27.03.2023	63.69	38.77	24.92	65.19	65.92	-1.11	63.99	65.47	-2.29	-1.48	7.00	6.00	1.594	24.0	0.0	
28.03.2023	64.73	39.77	24.96	72.30	73.07	-1.06	70.94	72.51	-2.19	-1.57	7.00	6.00	1.768	24.0	0.0	
29.03.2023	66.41	43.20	23.21	97.63	98.60	-0.99	95.70	97.73	-2.10	-2.03	7.00	6.00	2.220	24.0	0.0	
30.03.2023	65.63	42.91	22.72	96.70	97.77	-1.10	94.81	96.92	-2.20	-2.11	7.00	6.00	2.154	24.0	0.0	
31.03.2023	65.18	41.44	23.74	83.70	84.59	-1.06	82.09	83.88	-2.16	-1.79	7.00	6.00	1.948	24.0	0.0	
Средние:	68.46	43.94	24.52	---	---	-0.93	---	---	-2.14	---	7.00	6.00	---	---	---	
Итого:	---	---	---	3025.96	3053.79	---	2961.19	3024.97	---	-63.78	---	---	72.232	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
28.02.2023	61122.43	61800.49	59689.75	61088.85	-1399.10	1376.222	17837.0	4.0
31.03.2023	64148.39	64854.28	62650.94	64113.82	-1462.88	1448.454	18581.0	4.0
Итого:	3025.96	3053.79	2961.19	3024.97	-63.78	72.232	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Гашкова ул, д. 26/3 (ООО УК "КОД")
Прибор: ВКТ-7 Заводской номер: 00137628
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t2 °C	V1 м3	V2 м3	P1 кг/см2	P2 кг/см2	ВНР ч	ВОС ч	НС
01.03.2023	51.97	57.97	0.10	6.00	5.00	0.0	24.0	*
02.03.2023	54.29	57.90	0.11	6.00	5.00	0.0	24.0	*
03.03.2023	56.39	56.94	0.12	6.00	5.00	0.0	24.0	*
04.03.2023	51.26	58.11	0.11	6.00	5.00	0.0	24.0	*
05.03.2023	48.95	60.37	0.15	6.00	5.00	0.0	24.0	*
06.03.2023	50.26	56.99	0.11	6.00	5.00	0.0	24.0	*
07.03.2023	51.52	56.15	0.13	6.00	5.00	0.0	24.0	*
08.03.2023	52.21	56.81	0.11	6.00	5.00	0.0	24.0	*
09.03.2023	51.98	54.56	0.08	6.00	5.00	0.0	24.0	*
10.03.2023	51.43	54.48	0.10	6.00	5.00	0.0	24.0	*
11.03.2023	51.01	54.55	0.12	6.00	5.00	0.0	24.0	*
12.03.2023	51.46	56.10	0.18	6.00	5.00	0.0	24.0	*
13.03.2023	49.92	52.91	0.16	6.00	5.00	0.0	24.0	*
14.03.2023	49.14	53.01	0.14	6.00	5.00	0.0	24.0	*
15.03.2023	51.08	52.95	0.12	6.00	5.00	0.0	24.0	*
16.03.2023	50.69	52.95	0.09	6.00	5.00	0.0	24.0	*
17.03.2023	50.01	53.64	0.12	6.00	5.00	0.0	24.0	*
18.03.2023	50.34	54.63	0.12	6.00	5.00	0.0	24.0	*
19.03.2023	50.88	56.84	0.13	6.00	5.00	0.0	24.0	*
20.03.2023	50.23	54.73	0.10	6.00	5.00	0.0	24.0	*
21.03.2023	---	---	---	---	---	---	---	
22.03.2023	---	---	---	---	---	---	---	
23.03.2023	---	---	---	---	---	---	---	
24.03.2023	---	---	---	---	---	---	---	
25.03.2023	---	---	---	---	---	---	---	
26.03.2023	---	---	---	---	---	---	---	
27.03.2023	---	---	---	---	---	---	---	
28.03.2023	---	---	---	---	---	---	---	
29.03.2023	---	---	---	---	---	---	---	
30.03.2023	---	---	---	---	---	---	---	
31.03.2023	---	---	---	---	---	---	---	
Средние:	51.25	---	---	6.00	5.00	---	---	
Итого:	---	1112.60	2.41	---	---	0.0	480.0	

Дата	V1 м3	V2 м3	M1 т	M2 т	Mг т	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч
28.02.2023	30311.77	133.82	27554.93	127.98	27426.95	1508.161	1225.514	16857.0	984.0
20.03.2023	31424.36	136.23	27554.93	127.98	27426.95	1508.161	1225.514	16857.0	1464.0
Итого:	1112.60	2.41	0.00	0.00	0.00	0.000	0.000	0.0	480.0

Представитель абонента

Представитель энергоснабжающей организации
