

Отчет о суточных параметрах
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермский край, Пермь г, Сигаева ул, д. 6/1 (МКД)
Прибор: ВКТ-7 Заводской номер: 00123842
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система теплоснабжения, измерение расхода в трех трубопроводах (Схема 1)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2023	74.93	44.40	30.53	79.38	79.45	0.00	-0.09	77.39	78.70	-1.68	-1.31	6.50	4.50	2.362	24.0	0.0	
02.03.2023	78.46	50.20	28.26	115.01	115.07	0.00	-0.05	111.90	113.71	-1.60	-1.81	6.50	4.50	3.165	24.0	0.0	
03.03.2023	83.54	52.23	31.31	111.62	111.98	0.00	---	108.26	110.56	-2.10	-2.30	6.50	4.50	3.396	24.0	0.0	
04.03.2023	77.29	45.84	31.45	80.38	80.93	0.00	-0.68	78.28	80.12	-2.32	-1.84	6.50	4.50	2.462	24.0	0.0	
05.03.2023	75.23	42.85	32.38	67.32	67.97	0.00	-0.96	65.63	67.37	-2.62	-1.74	6.50	4.50	2.124	24.0	0.0	
06.03.2023	72.87	42.13	30.74	68.30	69.14	0.00	-1.22	66.69	68.56	-2.77	-1.87	6.50	4.50	2.050	24.0	0.0	
07.03.2023	72.79	42.90	29.89	74.28	74.63	0.00	-0.47	72.54	73.97	-1.95	-1.43	6.50	4.50	2.168	24.0	0.0	
08.03.2023	74.91	43.93	30.98	77.58	77.54	0.00	0.05	75.65	76.83	-1.55	-1.18	6.50	4.50	2.343	24.0	0.0	
09.03.2023	72.72	42.42	30.30	71.91	72.40	0.00	-0.68	70.20	71.77	-2.21	-1.57	6.50	4.50	2.127	24.0	0.0	*
10.03.2023	74.34	41.01	33.33	60.75	60.64	0.00	0.18	59.27	60.17	-1.51	-0.90	6.50	4.50	1.974	24.0	0.0	
11.03.2023	74.31	42.58	31.73	68.87	69.44	0.00	-0.82	67.19	68.85	-2.44	-1.66	6.50	4.50	2.132	24.0	0.0	
12.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
13.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
14.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
15.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
16.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
17.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
18.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
19.03.2023	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
20.03.2023	73.26	41.63	31.63	142.87	142.53	0.00	0.24	139.27	141.25	-1.41	-1.98	---	---	4.388	75.0	1.0	*
21.03.2023	73.17	41.53	31.64	62.33	63.48	0.00	-1.83	60.82	62.97	-3.47	-2.15	6.50	4.50	1.927	24.0	0.0	*
22.03.2023	72.94	40.92	32.02	59.36	60.44	0.00	-1.80	57.94	60.00	-3.49	-2.06	6.50	4.50	1.858	24.0	0.0	*
23.03.2023	72.49	41.38	31.11	62.07	63.29	0.00	-1.95	60.61	62.79	-3.53	-2.18	6.50	4.50	1.888	24.0	0.0	*
24.03.2023	72.03	39.45	32.58	52.55	53.66	0.00	-2.09	51.36	53.26	-3.63	-1.90	6.50	4.50	1.673	24.0	0.0	*
25.03.2023	72.41	38.96	33.45	51.77	52.92	0.00	-2.20	50.57	52.53	-3.80	-1.96	6.50	4.50	1.689	24.0	0.0	*
26.03.2023	72.77	39.02	33.75	49.48	50.60	0.00	-2.24	48.31	50.23	-3.90	-1.92	6.50	4.50	1.631	24.0	0.0	*
27.03.2023	72.44	38.52	33.92	46.65	47.73	0.00	-2.29	45.54	47.39	-3.98	-1.85	6.50	4.50	1.543	24.0	0.0	*
28.03.2023	72.53	39.41	33.12	50.45	51.61	0.00	-2.27	49.27	51.23	-3.90	-1.96	6.50	4.50	1.633	24.0	0.0	*
29.03.2023	72.64	42.26	30.38	67.44	69.02	0.00	-2.32	65.85	68.44	-3.86	-2.59	6.50	4.50	1.999	24.0	0.0	
30.03.2023	72.68	40.88	31.80	58.58	59.98	0.00	-2.36	57.22	59.49	-3.89	-2.27	6.50	4.50	1.822	24.0	0.0	*
31.03.2023	72.82	40.60	32.22	54.50	55.79	0.00	-2.34	53.23	55.35	-3.90	-2.12	6.50	4.50	1.716	24.0	0.0	*
Средние:	74.07	42.39	31.67	---	---	---	-1.24	---	---	-2.85	---	6.50	4.50	---	---	---	
Итого:	---	---	---	1633.45	1650.24	0.00	---	1592.99	1635.54	---	-42.55	---	---	50.070	603.0	1.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	Т	Т	Т	Гкал	ч	ч
28.02.2023	1919.56	1911.45	0.00	1868.14	1890.14	-22.00	55.804	466.0	26.0
31.03.2023	648.74	662.66	0.00	633.49	657.57	-24.08	20.417	278.0	0.0
Итого:	-1270.82	-1248.79	0.00	-1234.65	-1232.57	-2.08	-35.387	-188.0	-26.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Сигаева ул, д. 6/1 (ООО УК "КОД")
Прибор: ВКТ-7 Заводской номер: 123842
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система теплоснабжения, измерение расхода в трех трубопроводах (Схема 1)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
02.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
03.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
04.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
05.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
06.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
07.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
08.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
09.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
10.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
11.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
12.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
13.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
14.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
15.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
16.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
17.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
18.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
19.03.2023	---	---	---	---	---	---		---	---		---	---	---	---	---	---	
20.03.2023	73.26	41.63	31.63	142.87	142.53	0.00	0.24	139.27	141.25	-1.41	-1.98	---	---	4.388	75.0	1.0	*
21.03.2023	73.17	41.53	31.64	62.33	63.48	0.00	-1.83	60.82	62.97	-3.47	-2.15	6.50	4.50	1.927	24.0	0.0	*
22.03.2023	72.94	40.92	32.02	59.36	60.44	0.00	-1.80	57.94	60.00	-3.49	-2.06	6.50	4.50	1.858	24.0	0.0	*
23.03.2023	72.49	41.38	31.11	62.07	63.29	0.00	-1.95	60.61	62.79	-3.53	-2.18	6.50	4.50	1.888	24.0	0.0	*
24.03.2023	72.03	39.45	32.58	52.55	53.66	0.00	-2.09	51.36	53.26	-3.63	-1.90	6.50	4.50	1.673	24.0	0.0	*
25.03.2023	72.41	38.96	33.45	51.77	52.92	0.00	-2.20	50.57	52.53	-3.80	-1.96	6.50	4.50	1.689	24.0	0.0	*
26.03.2023	72.77	39.02	33.75	49.48	50.60	0.00	-2.24	48.31	50.23	-3.90	-1.92	6.50	4.50	1.631	24.0	0.0	*
27.03.2023	72.44	38.52	33.92	46.65	47.73	0.00	-2.29	45.54	47.39	-3.98	-1.85	6.50	4.50	1.543	24.0	0.0	*
28.03.2023	72.53	39.41	33.12	50.45	51.61	0.00	-2.27	49.27	51.23	-3.90	-1.96	6.50	4.50	1.633	24.0	0.0	*
29.03.2023	72.64	42.26	30.38	67.44	69.02	0.00	-2.32	65.85	68.44	-3.86	-2.59	6.50	4.50	1.999	24.0	0.0	*
30.03.2023	72.68	40.88	31.80	58.58	59.98	0.00	-2.36	57.22	59.49	-3.89	-2.27	6.50	4.50	1.822	24.0	0.0	*
31.03.2023	72.82	40.60	32.22	54.50	55.79	0.00	-2.34	53.23	55.35	-3.90	-2.12	6.50	4.50	1.716	24.0	0.0	*
Средние:	72.68	40.38	32.30	---	---	---	-1.95	---	---	-3.56	---	6.50	4.50	---	---	---	
Итого:	---	---	---	758.05	771.05	0.00	---	739.99	764.93	---	-24.94	---	---	23.767	339.0	1.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	т	т	т	Гкал	ч	ч
19.03.2023	0.00	0.00	0.00	0.00	0.00	0.00	0.000	73.7	0.0
31.03.2023	648.74	662.66	0.00	633.49	657.57	-24.08	20.417	278.0	0.0
Итого:	648.74	662.66	0.00	633.49	657.57	-24.08	20.417	204.3	0.0

Представитель абонента

Представитель энергоснабжающей организации
