

Отчет о суточных параметрах  
(01.03.2023 0:00:00 - 31.03.2023 0:00:00)

Объект: Пермь г, Хрустальная ул, д. 30 (ООО УК "КОД")

Прибор: ТВ7 Заводской номер: 20137965

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	dM	P1	P2	Qтв	ВНР	ВОС	tx	НС
	°C	°C	°C	м3	м3	т	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	°C	
01.03.2023	59.10	47.75	11.36	425.96	420.09	419.11	415.68	0.82	3.44	5.71	5.34	4.761	24.0	0.0	0.00	
02.03.2023	64.12	50.95	13.17	428.11	421.80	420.09	416.74	0.80	3.35	5.69	5.33	5.534	24.0	0.0	0.00	
03.03.2023	68.22	53.71	14.51	428.65	422.00	419.65	416.37	0.79	3.28	5.55	5.19	6.093	24.0	0.0	0.00	
04.03.2023	61.03	49.35	11.68	428.43	422.45	421.12	417.69	0.82	3.42	5.49	5.12	4.921	24.0	0.0	0.00	
05.03.2023	55.61	45.76	9.85	428.59	423.00	422.51	418.91	0.86	3.60	5.57	5.20	4.164	24.0	0.0	0.00	
06.03.2023	55.20	45.45	9.75	428.52	422.94	422.48	418.94	0.84	3.53	5.57	5.21	4.121	24.0	0.0	0.00	
07.03.2023	57.97	47.20	10.76	427.69	421.92	421.08	417.58	0.83	3.50	5.67	5.30	4.534	24.0	0.0	0.00	
08.03.2023	58.26	47.45	10.80	427.97	422.20	421.29	417.84	0.82	3.45	5.69	5.33	4.552	24.0	0.0	0.00	
09.03.2023	53.80	44.63	9.17	427.61	422.15	421.85	418.28	0.85	3.58	5.65	5.29	3.869	24.0	0.0	0.00	
10.03.2023	49.80	41.90	7.90	427.09	421.89	422.22	418.54	0.88	3.68	5.62	5.26	3.335	24.0	0.0	0.00	
11.03.2023	53.72	44.29	9.42	427.49	422.01	421.79	418.23	0.85	3.55	5.70	5.33	3.975	24.0	0.0	0.00	
12.03.2023	58.13	47.36	10.77	427.90	422.16	421.26	417.80	0.83	3.46	5.69	5.32	4.540	24.0	0.0	0.00	
13.03.2023	49.99	42.22	7.77	430.21	425.00	425.24	421.55	0.87	3.69	5.52	5.15	3.305	24.0	0.0	0.00	
14.03.2023	53.62	44.40	9.22	431.71	426.25	425.99	422.42	0.84	3.56	5.70	5.33	3.929	24.0	0.0	0.00	
15.03.2023	51.13	43.03	8.10	436.71	431.36	431.44	427.72	0.87	3.72	5.63	5.24	3.496	24.0	0.0	0.00	
16.03.2023	49.38	41.77	7.60	434.72	429.74	429.80	426.34	0.81	3.46	4.89	4.48	3.269	24.0	0.0	0.00	
17.03.2023	47.50	40.67	6.84	436.35	431.46	431.82	428.26	0.83	3.56	5.55	5.12	2.953	24.0	0.0	0.00	
18.03.2023	49.86	42.00	7.86	435.06	429.90	430.05	426.44	0.84	3.61	5.81	5.40	3.381	24.0	0.0	0.00	
19.03.2023	57.25	47.05	10.19	436.49	430.87	429.91	426.48	0.80	3.43	5.87	5.47	4.384	24.0	0.0	0.00	
20.03.2023	52.42	44.05	8.37	436.23	431.10	430.69	427.28	0.80	3.41	5.90	5.50	3.605	24.0	0.0	0.00	
21.03.2023	49.72	42.14	7.57	436.08	431.18	431.14	427.72	0.80	3.42	5.85	5.45	3.266	24.0	0.0	0.00	
22.03.2023	48.31	41.20	7.10	436.08	431.28	431.38	427.95	0.80	3.42	5.77	5.37	3.065	24.0	0.0	0.00	
23.03.2023	49.70	42.00	7.71	436.56	431.11	431.58	427.67	0.91	3.90	5.84	5.45	3.326	24.0	0.0	0.00	
24.03.2023	46.86	40.28	6.58	435.92	430.62	431.50	427.50	0.93	4.00	5.69	5.30	2.842	24.0	0.0	0.00	
25.03.2023	45.22	39.06	6.16	435.33	430.12	431.26	427.20	0.95	4.06	5.56	5.17	2.656	24.0	0.0	0.00	
26.03.2023	45.63	39.09	6.55	384.74	380.08	381.07	377.49	0.94	3.58	5.53	5.18	2.495	24.0	0.0	0.00	*
27.03.2023	43.62	38.18	5.44	446.15	441.12	442.27	438.25	0.91	4.02	5.52	5.12	2.409	24.0	0.0	0.00	
28.03.2023	45.64	39.46	6.18	446.02	440.85	441.77	437.77	0.91	4.00	5.60	5.19	2.732	24.0	0.0	0.00	
29.03.2023	52.57	44.20	8.38	446.92	441.41	441.20	437.46	0.85	3.74	5.91	5.51	3.697	24.0	0.0	0.00	
30.03.2023	51.06	43.31	7.76	446.90	441.52	441.55	437.77	0.86	3.79	5.85	5.45	3.426	24.0	0.0	0.00	
31.03.2023	48.09	41.26	6.83	446.53	441.32	441.77	437.93	0.87	3.84	5.72	5.31	3.018	24.0	0.0	0.00	
Средние:	52.66	43.91	8.75	---	---	---	---	0.85	---	5.66	5.27	---	---	---	0.00	
Итого:	---	---	---	13408.70	13240.89	13235.88	13123.80	---	112.08	---	---	115.653	744.0	0.0	---	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
28.02.2023	69002.51	67846.73	66058.62	65335.27	723.35	775.744	0.000	0.000	4377.0	119.0
31.03.2023	82411.21	81087.62	79294.50	78459.07	835.43	891.397	0.000	0.000	5121.0	119.0
Итого:	13408.70	13240.89	13235.88	13123.80	112.08	115.653	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации