

Отчет о суточных параметрах
(01.05.2023 0:00:00 - 31.05.2023 0:00:00)

Объект: Пермский край, Пермь г, Гашкова ул, д. 45 (МКД)
Прибор: СПТ941.10(11) Заводской номер: 39046
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в трёх трубопроводах) (Схема 3)

Дата	t1	t2	dt	V1	V2	V3	M1	M2	M3	%	Q	Ти	NS
	°C	°C	°C	м3	м3	м3	т	т	т	т	Гкал	ч	
01.05.2023	21.38	20.83	0.55	800.84	800.84	0.00	799.40	799.47	0.00	-0.01	0.46	24.00	
02.05.2023	20.47	20.10	0.37	975.94	976.06	0.00	974.38	974.53	0.00	-0.02	0.38	24.00	
03.05.2023	20.33	19.99	0.34	336.45	336.45	0.00	335.92	335.93	0.00	0.00	0.12	24.00	
04.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
05.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
06.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
07.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
08.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
09.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
10.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
11.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
12.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
13.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
14.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
15.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
16.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
17.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
18.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
19.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
20.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
21.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
22.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
23.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
24.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
25.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
26.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
27.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
28.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
29.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
30.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
31.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	20.73	20.31	0.42	---	---	---	---	---	---	-0.01	---	---	
Итого:	---	---	---	2113.24	2113.35	0.00	2109.71	2109.93	0.00	---	0.96	72.00	

Дата	V1	V2	V3	M1	M2	M3	Q	Ти
	м3	м3	м3	т	т	т	Гкал	ч
30.04.2023	178596.92	169010.37	20.50	174227.52	167082.51	0.00	4417.92	31645.63
03.05.2023	180710.16	171123.73	20.50	176337.22	169192.44	0.00	4418.88	31717.63
Итого:	2113.24	2113.35	0.00	2109.71	2109.93	0.00	0.96	72.00

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.05.2023 0:00:00 - 31.05.2023 0:00:00)

Объект: Пермь г, Гашкова ул, д. 45 (ООО УК "КОД")
Прибор: СПТ941.10(11) Заводской номер: 39046
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в трёх трубопроводах) (Схема 3)

Дата	t1	t2	dt	V1	V2	V3	M1	M2	M3	%	Q	Ти	NS
	°C	°C	°C	м3	м3	м3	т	т	т	т	Гкал	ч	
01.05.2023	21.38	20.83	0.55	800.84	800.84	0.00	799.40	799.47	0.00	-0.01	0.46	24.00	
02.05.2023	20.47	20.10	0.37	975.94	976.06	0.00	974.38	974.53	0.00	-0.02	0.38	24.00	
03.05.2023	20.33	19.99	0.34	336.45	336.45	0.00	335.92	335.93	0.00	0.00	0.12	24.00	
04.05.2023	18.54	18.46	0.08	0.00	0.00	0.00	0.00	0.00	0.00	---	0.00	24.00	
05.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
06.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
07.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
08.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
09.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
10.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
11.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
12.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
13.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
14.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
15.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
16.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
17.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
18.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
19.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
20.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
21.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
22.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
23.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
24.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
25.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
26.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
27.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
28.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
29.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
30.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
31.05.2023	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	20.18	19.84	0.34	---	---	---	---	---	---	-0.01	---	---	
Итого:	---	---	---	2113.24	2113.35	0.00	2109.71	2109.93	0.00	---	0.96	96.00	

Дата	V1	V2	V3	M1	M2	M3	Q	Ти
	м3	м3	м3	т	т	т	Гкал	ч
30.04.2023	178596.92	169010.37	20.50	174227.52	167082.51	0.00	4417.92	31645.63
04.05.2023	180710.16	171123.73	20.50	176337.22	169192.44	0.00	4418.88	31741.63
Итого:	2113.24	2113.35	0.00	2109.71	2109.93	0.00	0.96	96.00

Представитель абонента

Представитель энергоснабжающей организации