

Отчет о суточных параметрах
(01.09.2023 0:00:00 - 30.09.2023 0:00:00)

Объект: Пермь г, Целинная ул, д. 29/1 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 137623

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	Т	кг/см2	кг/см2	Гкал	ч	
01.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
02.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
03.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
04.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
05.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
06.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
07.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
08.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
09.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
10.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
11.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
12.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
13.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
14.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
15.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
16.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
17.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
18.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
19.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
20.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
21.09.2023	---	---	---	---	---		---	---		---	7.00	7.00	---	0.0	24.0	*
22.09.2023	47.11	41.59	5.52	0.90	1.20	-28.57	0.90	1.20	-28.57	-0.30	7.00	7.00	0.009	9.0	15.0	*
23.09.2023	46.94	41.59	5.35	2.38	3.15	-27.85	2.38	3.15	-27.85	-0.77	7.00	7.00	0.022	24.0	0.0	*
24.09.2023	46.79	41.66	5.13	2.37	3.15	-28.26	2.37	3.15	-28.26	-0.78	7.00	7.00	0.017	24.0	0.0	*
25.09.2023	47.56	42.25	5.31	2.33	3.12	-28.99	2.33	3.12	-28.99	-0.79	7.00	7.00	0.018	24.0	0.0	*
26.09.2023	69.42	38.89	30.53	26.55	26.75	-0.75	25.98	26.60	-2.36	-0.62	7.00	7.00	0.798	24.0	0.0	*
27.09.2023	70.39	55.11	15.28	198.28	196.59	0.86	193.89	193.81	0.04	0.08	7.00	7.00	2.959	24.0	0.0	
28.09.2023	70.43	56.09	14.34	213.96	212.89	0.50	209.21	209.78	-0.27	-0.57	7.00	7.00	2.999	24.0	0.0	
29.09.2023	68.55	53.36	15.19	133.09	132.46	0.47	130.26	130.72	-0.35	-0.46	7.00	7.00	1.973	24.0	0.0	*
30.09.2023	65.93	29.46	36.47	10.35	10.77	-3.98	10.11	10.77	-6.32	-0.66	7.00	7.00	0.368	24.0	0.0	*
Средние:	59.24	44.44	14.79	---	---	-12.95	---	---	-13.66	---	7.00	7.00	---	---	---	
Итого:	---	---	---	590.21	590.08	---	577.43	582.30	---	-4.87	---	---	9.163	201.0	519.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.08.2023	0.00	0.00	0.00	0.00	0.00	0.000	0.0	1164.0
30.09.2023	590.21	590.08	577.43	582.30	-4.87	9.163	201.0	1683.0
Итого:	590.21	590.08	577.43	582.30	-4.87	9.163	201.0	519.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.09.2023 0:00:00 - 30.09.2023 0:00:00)

Объект: Пермь г, Целинная ул, д. 29/1 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 137623

Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	V1	V2	P1	P2	ВНР	ВОС	НС
	м3	м3	кг/см2	кг/см2	ч	ч	
01.09.2023	---	---	7.00	7.00	0.0	24.0	*
02.09.2023	---	---	7.00	7.00	0.0	24.0	*
03.09.2023	---	---	7.00	7.00	0.0	24.0	*
04.09.2023	---	---	7.00	7.00	0.0	24.0	*
05.09.2023	---	---	7.00	7.00	0.0	24.0	*
06.09.2023	---	---	7.00	7.00	0.0	24.0	*
07.09.2023	---	---	7.00	7.00	0.0	24.0	*
08.09.2023	---	---	7.00	7.00	0.0	24.0	*
09.09.2023	---	---	7.00	7.00	0.0	24.0	*
10.09.2023	---	---	7.00	7.00	0.0	24.0	*
11.09.2023	---	---	7.00	7.00	0.0	24.0	*
12.09.2023	---	---	7.00	7.00	0.0	24.0	*
13.09.2023	---	---	7.00	7.00	0.0	24.0	*
14.09.2023	---	---	7.00	7.00	0.0	24.0	*
15.09.2023	---	---	7.00	7.00	0.0	24.0	*
16.09.2023	---	---	7.00	7.00	0.0	24.0	*
17.09.2023	---	---	7.00	7.00	0.0	24.0	*
18.09.2023	---	---	7.00	7.00	0.0	24.0	*
19.09.2023	---	---	7.00	7.00	0.0	24.0	*
20.09.2023	---	---	7.00	7.00	0.0	24.0	*
21.09.2023	---	---	7.00	7.00	0.0	24.0	*
22.09.2023	23.43	19.86	7.00	7.00	0.0	24.0	*
23.09.2023	59.33	53.23	7.00	7.00	0.0	24.0	*
24.09.2023	61.32	53.29	7.00	7.00	0.0	24.0	*
25.09.2023	58.93	53.74	7.00	7.00	0.0	24.0	*
26.09.2023	---	---	---	---	---	---	
27.09.2023	---	---	---	---	---	---	
28.09.2023	---	---	---	---	---	---	
29.09.2023	---	---	---	---	---	---	
30.09.2023	---	---	---	---	---	---	
Средние:	---	---	7.00	7.00	---	---	
Итого:	203.01	180.12	---	---	0.0	600.0	

Дата	V1	V2	M1	M2	Mг	Qo	Qg	ВНР	ВОС
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
31.08.2023	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.0	1164.0
25.09.2023	203.01	180.12	0.00	0.00	0.00	0.000	0.000	0.0	1764.0
Итого:	203.01	180.12	0.00	0.00	0.00	0.000	0.000	0.0	600.0

Представитель абонента

Представитель энергоснабжающей организации