

Отчет о суточных параметрах  
(01.11.2023 0:00:00 - 30.11.2023 0:00:00)

Объект: Пермь г, Зенкова ул, д. 4 (Население ПР (ООО УК "КОД"))

Прибор: ВКТ-7 Заводской номер: 168399

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.11.2023	53.67	43.94	9.73	242.89	244.10	-0.50	239.67	241.92	-0.93	-2.25	7.00	7.00	2.329	24.0	0.0	
02.11.2023	49.39	41.22	8.17	239.15	240.62	-0.61	236.43	238.73	-0.97	-2.30	7.00	7.00	1.927	24.0	0.0	
03.11.2023	44.15	37.65	6.50	237.96	239.66	-0.71	235.80	238.07	-0.96	-2.27	7.00	7.00	1.531	24.0	0.0	
04.11.2023	52.99	43.14	9.85	241.14	242.32	-0.49	237.99	240.26	-0.95	-2.27	7.00	7.00	2.341	24.0	0.0	
05.11.2023	54.19	44.11	10.08	242.72	243.91	-0.49	239.40	241.75	---	-2.35	7.00	7.00	2.409	24.0	0.0	
06.11.2023	51.83	42.65	9.18	243.14	244.52	-0.57	240.10	242.46	-0.98	-2.36	7.00	7.00	2.199	24.0	0.0	
07.11.2023	47.34	39.93	7.41	242.80	244.39	-0.65	240.26	242.57	-0.96	-2.31	7.00	7.00	1.779	24.0	0.0	
08.11.2023	46.89	39.63	7.26	241.49	243.15	-0.69	239.01	241.35	-0.97	-2.34	7.00	7.00	1.732	24.0	0.0	
09.11.2023	47.16	39.87	7.29	242.33	243.91	-0.65	239.78	242.06	-0.95	-2.28	7.00	7.00	1.744	24.0	0.0	
10.11.2023	46.46	39.39	7.07	240.87	242.51	-0.68	238.43	240.77	-0.98	-2.34	7.00	7.00	1.680	24.0	0.0	
11.11.2023	46.75	39.57	7.18	242.22	243.84	-0.67	239.72	242.07	-0.98	-2.35	7.00	7.00	1.718	24.0	0.0	
12.11.2023	48.51	40.48	8.03	235.76	237.24	-0.63	233.16	235.45	-0.98	-2.29	7.00	7.00	1.867	24.0	0.0	
13.11.2023	49.34	40.94	8.40	235.89	237.38	-0.63	233.21	235.49	-0.97	-2.28	7.00	7.00	1.952	24.0	0.0	
14.11.2023	45.84	38.76	7.08	235.04	236.69	-0.70	232.74	235.00	-0.97	-2.26	7.00	7.00	1.645	24.0	0.0	
15.11.2023	48.14	40.27	7.87	235.33	236.87	-0.65	232.78	235.06	-0.97	-2.28	7.00	7.00	1.829	24.0	0.0	
16.11.2023	49.99	41.45	8.54	233.87	235.30	-0.61	231.15	233.39	-0.96	-2.24	7.00	7.00	1.969	24.0	0.0	
17.11.2023	53.85	43.60	10.25	235.68	236.82	-0.48	232.54	234.72	-0.93	-2.18	7.00	7.00	2.378	24.0	0.0	
18.11.2023	60.50	47.44	13.06	236.36	237.04	-0.29	232.36	234.55	-0.94	-2.19	7.00	7.00	3.029	24.0	0.0	
19.11.2023	62.88	48.92	13.96	236.54	237.05	-0.22	232.25	234.42	-0.93	-2.17	7.00	7.00	3.239	24.0	0.0	
20.11.2023	60.03	47.30	12.73	236.26	237.05	-0.33	232.35	234.58	-0.96	-2.23	7.00	7.00	2.954	24.0	0.0	
21.11.2023	59.70	46.85	12.85	229.20	229.97	-0.34	225.49	227.64	-0.95	-2.15	7.00	7.00	2.892	24.0	0.0	
22.11.2023	59.51	46.56	12.95	224.27	225.05	-0.35	220.67	222.74	-0.93	-2.07	7.00	7.00	2.855	24.0	0.0	
23.11.2023	61.67	47.79	13.88	224.04	224.68	-0.29	220.15	222.28	-0.96	-2.13	7.00	7.00	3.050	24.0	0.0	
24.11.2023	68.54	52.02	16.52	229.93	230.14	-0.09	225.06	227.27	-0.98	-2.21	7.00	7.00	3.712	24.0	0.0	
25.11.2023	66.20	50.56	15.64	226.01	226.36	-0.15	221.54	223.68	-0.96	-2.14	7.00	7.00	3.463	24.0	0.0	
26.11.2023	55.63	44.42	11.21	225.22	226.28	-0.47	221.97	224.21	-1.00	-2.24	7.00	7.00	2.484	24.0	0.0	
27.11.2023	50.35	41.19	9.16	224.68	226.03	-0.60	222.05	224.23	-0.98	-2.18	7.00	7.00	2.034	24.0	0.0	
28.11.2023	53.70	43.30	10.40	224.99	226.16	-0.52	222.00	224.21	-0.99	-2.21	7.00	7.00	2.306	24.0	0.0	
29.11.2023	52.72	42.73	9.99	225.00	226.23	-0.55	222.11	224.31	-0.99	-2.20	7.00	7.00	2.214	24.0	0.0	
30.11.2023	54.71	43.84	10.87	225.22	226.28	-0.47	222.10	224.24	-0.96	-2.14	7.00	7.00	2.410	24.0	0.0	
Средние:	53.42	43.32	10.10	---	---	-0.50	---	---	-0.96	---	7.00	7.00	---	---	---	
Итого:	---	---	---	7036.00	7071.55	---	6942.27	7009.48	---	-67.21	---	---	69.671	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.10.2023	7136.14	7182.81	7064.50	7131.64	-67.14	48.476	997.0	1848.0
30.11.2023	14172.14	14254.36	14006.77	14141.12	-134.35	118.147	1717.0	1848.0
Итого:	7036.00	7071.55	6942.27	7009.48	-67.21	69.671	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.11.2023 0:00:00 - 30.11.2023 0:00:00)

Объект: Пермь г, Зенкова ул, д. 4 (Население ПР (ООО УК "КОД"))

Прибор: ВКТ-7 Заводской номер: 168399

Точка измерения: ТВ2 (нет акта допуска); Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t2 °C	V1 м3	V2 м3	P1 кг/см2	P2 кг/см2	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч	НС
01.11.2023	---	0.00	22.51	7.00	7.00	14748.36	14748.36	0.0	24.0	*
02.11.2023	55.07	0.00	21.61	7.00	7.00	14748.36	14748.36	0.0	24.0	*
03.11.2023	29.52	0.00	16.83	7.00	7.00	14748.36	14748.36	0.0	24.0	*
04.11.2023	---	0.00	18.21	7.00	7.00	14748.36	14748.36	0.0	24.0	*
05.11.2023	27.10	0.00	22.43	7.00	7.00	14748.36	14748.36	0.0	24.0	*
06.11.2023	18.22	0.00	22.39	7.00	7.00	14748.36	14748.36	0.0	24.0	*
07.11.2023	---	0.00	22.48	7.00	7.00	14748.36	14748.36	0.0	24.0	*
08.11.2023	---	0.00	22.37	7.00	7.00	14748.36	14748.36	0.0	24.0	*
09.11.2023	---	0.00	22.23	7.00	7.00	14748.36	14748.36	0.0	24.0	*
10.11.2023	---	0.00	22.26	7.00	7.00	14748.36	14748.36	0.0	24.0	*
11.11.2023	73.69	0.00	22.31	7.00	7.00	14748.36	14748.36	0.0	24.0	*
12.11.2023	69.76	0.00	22.25	7.00	7.00	14748.36	14748.36	0.0	24.0	*
13.11.2023	---	0.00	22.34	7.00	7.00	14748.36	14748.36	0.0	24.0	*
14.11.2023	9.46	0.00	22.02	7.00	7.00	14748.36	14748.36	0.0	24.0	*
15.11.2023	28.14	0.00	22.04	7.00	7.00	14748.36	14748.36	0.0	24.0	*
16.11.2023	---	0.00	21.80	7.00	7.00	14748.36	14748.36	0.0	24.0	*
17.11.2023	---	0.00	21.83	7.00	7.00	14748.36	14748.36	0.0	24.0	*
18.11.2023	20.93	0.00	21.82	7.00	7.00	14748.36	14748.36	0.0	24.0	*
19.11.2023	---	0.00	21.62	7.00	7.00	14748.36	14748.36	0.0	24.0	*
20.11.2023	0.11	0.00	21.65	7.00	7.00	14748.36	14748.36	0.0	24.0	*
21.11.2023	---	0.00	21.65	7.00	7.00	14748.36	14748.36	0.0	24.0	*
22.11.2023	---	0.00	21.63	7.00	7.00	14748.36	14748.36	0.0	24.0	*
23.11.2023	---	0.00	21.58	7.00	7.00	14748.36	14748.36	0.0	24.0	*
24.11.2023	---	0.00	20.84	7.00	7.00	14748.36	14748.36	0.0	24.0	*
25.11.2023	11.48	0.00	21.71	7.00	7.00	14748.36	14748.36	0.0	24.0	*
26.11.2023	---	18.51	22.69	7.00	7.00	14748.36	14748.36	0.0	24.0	*
27.11.2023	---	33.53	23.54	7.00	7.00	14748.36	14748.36	0.0	24.0	*
28.11.2023	---	32.54	23.62	7.00	7.00	14748.36	14748.36	0.0	24.0	*
29.11.2023	---	32.89	23.55	7.00	7.00	14748.36	14748.36	0.0	24.0	*
30.11.2023	---	33.37	22.86	7.00	7.00	14748.36	14748.36	0.0	24.0	*
Средние:	31.23	---	---	7.00	7.00	---	---	---	---	
Итого:	---	150.84	656.68	---	---	442450.94	442450.94	0.0	720.0	

Дата	V1 м3	V2 м3	M1 т	M2 т	Mг т	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч
31.10.2023	0.70	904.28	0.68	0.68	0.00	-1288490.189	-1288490.189	2.0	2843.0
30.11.2023	151.53	1560.96	0.68	0.68	0.00	-1073741.824	-1073741.824	2.0	3563.0
Итого:	150.84	656.68	0.00	0.00	0.00	214748.365	214748.365	0.0	720.0

Представитель абонента

Представитель энергоснабжающей организации