

Отчет о суточных параметрах
(01.01.2024 0:00:00 - 31.01.2024 0:00:00)

Объект: Пермь г, Хрустальная ул, д. 30 (ООО УК "КОД")
Прибор: ТВ7 Заводской номер: 20137965
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	dM	P1	P2	Qтв	ВНР	ВОС	tx	НС
	°C	°C	°C	м3	м3	т	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	°C	
01.01.2024	73.22	57.71	15.51	456.60	450.73	445.70	443.80	0.43	1.90	5.08	4.68	6.920	24.0	0.0	0.00	
02.01.2024	77.05	59.81	17.24	457.50	451.15	445.54	443.72	0.41	1.82	5.39	4.99	7.691	24.0	0.0	0.00	
03.01.2024	78.12	60.36	17.76	457.50	451.03	445.27	443.49	0.40	1.79	5.36	4.95	7.918	24.0	0.0	0.00	
04.01.2024	76.76	59.66	17.11	456.80	450.56	444.94	443.19	0.39	1.74	5.20	4.80	7.621	24.0	0.0	0.00	
05.01.2024	76.55	59.48	17.07	455.28	449.00	443.52	441.68	0.41	1.83	5.00	4.59	7.581	24.0	0.0	0.00	
06.01.2024	78.11	60.21	17.90	456.42	450.00	444.20	442.53	0.38	1.66	5.28	4.88	7.962	24.0	0.0	0.00	
07.01.2024	79.24	61.07	18.17	456.54	450.09	444.01	442.41	0.36	1.60	5.32	4.92	8.080	24.0	0.0	0.00	
08.01.2024	79.09	60.85	18.23	456.34	449.92	443.88	442.26	0.37	1.62	5.33	4.93	8.105	24.0	0.0	0.00	
09.01.2024	77.40	59.79	17.61	455.41	449.25	443.42	441.85	0.36	1.57	5.22	4.82	7.820	24.0	0.0	0.00	
10.01.2024	77.32	59.54	17.79	453.24	447.06	441.34	439.78	0.35	1.56	5.31	4.90	7.860	24.0	0.0	0.00	
11.01.2024	80.34	61.44	18.90	452.00	445.48	439.29	437.78	0.34	1.51	5.61	5.19	8.316	24.0	0.0	0.00	
12.01.2024	80.21	61.46	18.74	450.97	444.59	438.33	436.90	0.33	1.42	5.58	5.16	8.227	24.0	0.0	0.00	
13.01.2024	80.12	61.28	18.83	450.59	444.20	437.98	436.56	0.33	1.43	5.67	5.26	8.260	24.0	0.0	0.00	
14.01.2024	79.47	60.97	18.50	450.91	444.67	438.47	437.10	0.31	1.37	5.60	5.19	8.122	24.0	0.0	0.00	
15.01.2024	72.37	56.55	15.82	449.54	444.15	439.05	437.59	0.33	1.47	5.41	5.00	6.952	24.0	0.0	0.00	
16.01.2024	66.46	52.62	13.84	449.75	444.92	440.78	439.22	0.35	1.55	5.58	5.16	6.104	24.0	0.0	0.00	
17.01.2024	62.38	49.88	12.50	447.60	443.19	439.66	438.08	0.36	1.57	5.39	4.97	5.498	24.0	0.0	0.00	
18.01.2024	63.33	50.49	12.84	446.67	442.20	438.50	437.00	0.34	1.50	5.55	5.14	5.635	24.0	0.0	0.00	
19.01.2024	64.43	51.22	13.22	447.06	442.49	438.64	437.12	0.35	1.52	5.62	5.21	5.802	24.0	0.0	0.00	
20.01.2024	58.39	47.55	10.85	446.34	442.33	439.32	437.71	0.37	1.61	5.24	4.83	4.767	24.0	0.0	0.00	
21.01.2024	57.86	47.12	10.74	446.86	442.87	439.98	438.32	0.38	1.66	5.48	5.07	4.727	24.0	0.0	0.00	
22.01.2024	65.32	52.05	13.27	447.96	443.34	439.29	437.79	0.34	1.50	5.67	5.26	5.836	24.0	0.0	0.00	
23.01.2024	67.11	53.38	13.73	447.77	443.03	438.65	437.18	0.34	1.47	5.38	4.97	6.027	24.0	0.0	0.00	
24.01.2024	66.06	52.85	13.21	447.43	442.86	438.60	437.15	0.33	1.45	5.29	4.88	5.799	24.0	0.0	0.00	
25.01.2024	65.20	52.28	12.92	446.82	442.33	438.19	436.72	0.34	1.47	5.23	4.81	5.667	24.0	0.0	0.00	
26.01.2024	64.95	52.11	12.84	446.48	442.05	437.93	436.47	0.33	1.45	5.16	4.75	5.628	24.0	0.0	0.00	
27.01.2024	65.16	52.21	12.94	446.47	442.04	437.86	436.47	0.32	1.40	5.22	4.80	5.672	24.0	0.0	0.00	
28.01.2024	63.99	51.50	12.49	446.39	442.07	438.08	436.66	0.32	1.42	5.33	4.92	5.477	24.0	0.0	0.00	
29.01.2024	62.90	50.76	12.14	446.48	442.27	438.43	437.00	0.33	1.43	5.43	5.02	5.324	24.0	0.0	0.00	
30.01.2024	60.97	49.56	11.41	446.26	442.23	438.66	437.22	0.33	1.44	5.34	4.93	5.008	24.0	0.0	0.00	
31.01.2024	56.24	46.57	9.68	445.93	442.29	439.41	437.87	0.35	1.55	5.29	4.87	4.254	24.0	0.0	0.00	
Средние:	70.20	55.24	14.96	---	---	---	---	0.35	---	5.37	4.96	---	---	---	0.00	
Итого:	---	---	---	13967.93	13804.36	13656.90	13608.61	---	48.29	---	---	204.662	744.0	0.0	---	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
31.12.2023	138005.41	135990.29	134143.48	132833.98	1309.50	1350.152	0.000	0.000	11669.0	171.0
31.01.2024	151973.34	149794.65	147800.38	146442.59	1357.79	1554.813	0.000	0.000	12413.0	171.0
Итого:	13967.93	13804.37	13656.90	13608.61	48.29	204.662	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации