

Отчет о суточных параметрах  
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермский край, Пермь г, Баранчинская ул, д. 2 (МКД)  
Прибор: ВКТ-7 Заводской номер: 00123848  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система теплоснабжения, измерение расхода в трех трубопроводах (Схема 1)

Дата	t1	t2	dt	V1	V2	V3	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2024	69.58	48.85	20.73	116.97	110.57	0.00	5.63	114.45	109.33	4.58	5.12	8.00	6.00	2.375	24.0	0.0	
02.03.2024	69.27	49.21	20.06	119.98	113.59	0.00	5.47	117.43	112.32	4.45	5.11	8.00	6.00	2.357	24.0	0.0	
03.03.2024	69.67	49.60	20.07	119.62	113.34	0.00	5.39	117.01	112.06	4.32	4.95	8.00	6.00	2.349	24.0	0.0	
04.03.2024	69.47	49.89	19.58	121.71	115.44	0.00	5.29	119.09	114.08	4.30	5.01	8.00	6.00	2.334	24.0	0.0	
05.03.2024	69.41	49.65	19.76	119.45	113.32	0.00	5.27	116.88	111.97	4.29	4.91	8.00	6.00	2.313	24.0	0.0	
06.03.2024	70.73	48.41	22.32	109.71	103.81	0.00	5.53	107.26	102.69	4.35	4.57	8.00	6.00	2.396	24.0	0.0	
07.03.2024	70.62	48.32	22.30	110.99	105.09	0.00	5.46	108.53	103.90	4.36	4.63	8.00	6.00	2.423	24.0	0.0	
08.03.2024	68.30	46.35	21.95	101.88	96.31	0.00	5.62	99.72	95.33	4.50	4.39	8.00	6.00	2.190	24.0	0.0	
09.03.2024	65.02	42.28	22.74	82.39	77.05	0.00	6.70	80.78	76.41	5.56	4.37	8.00	6.00	1.835	24.0	0.0	
10.03.2024	68.24	42.54	25.70	83.55	77.13	0.00	7.99	81.84	76.43	6.84	5.41	8.00	6.00	2.104	24.0	0.0	
11.03.2024	66.57	40.21	26.36	52.82	49.79	0.00	5.91	51.75	49.39	4.67	2.36	8.00	6.00	1.354	24.0	0.0	*
12.03.2024	69.17	41.62	27.55	84.98	78.43	0.00	8.02	83.17	77.75	6.74	5.42	8.00	6.00	2.291	24.0	0.0	
13.03.2024	69.38	42.56	26.82	83.73	78.33	0.00	6.66	81.93	77.61	5.42	4.32	8.00	6.00	2.198	24.0	0.0	
14.03.2024	67.64	43.72	23.92	90.42	85.14	0.00	6.02	88.55	84.39	4.81	4.16	8.00	6.00	2.117	24.0	0.0	
15.03.2024	67.70	44.50	23.20	92.37	86.95	0.00	6.05	90.47	86.17	4.87	4.30	8.00	6.00	2.099	24.0	0.0	
16.03.2024	67.40	45.96	21.44	101.77	95.85	0.00	5.99	99.68	94.93	4.88	4.75	8.00	6.00	2.141	24.0	0.0	
17.03.2024	68.04	47.93	20.11	113.53	107.08	0.00	5.85	111.19	105.95	4.83	5.24	8.00	6.00	2.236	24.0	0.0	
18.03.2024	68.38	47.09	21.29	102.95	96.70	0.00	6.26	100.79	95.69	5.19	5.10	8.00	6.00	2.147	24.0	0.0	
19.03.2024	67.86	45.18	22.68	93.23	87.67	0.00	6.15	91.29	86.82	5.02	4.47	8.00	6.00	2.072	24.0	0.0	
20.03.2024	67.58	45.80	21.78	96.39	91.10	0.00	5.64	94.42	90.19	4.58	4.23	8.00	6.00	2.056	24.0	0.0	
21.03.2024	67.73	46.01	21.72	96.77	91.63	0.00	5.46	94.79	90.70	4.41	4.09	8.00	6.00	2.059	24.0	0.0	
22.03.2024	67.37	46.26	21.11	98.79	93.66	0.00	5.33	96.79	92.70	4.32	4.09	8.00	6.00	2.042	24.0	0.0	
23.03.2024	67.00	45.96	21.04	97.84	92.65	0.00	5.45	95.89	91.69	4.48	4.20	8.00	6.00	2.016	24.0	0.0	
24.03.2024	66.86	45.39	21.47	95.38	90.23	0.00	5.55	93.48	89.32	4.55	4.16	8.00	6.00	2.008	24.0	0.0	
25.03.2024	67.39	45.52	21.87	94.79	89.65	0.00	5.57	92.85	88.70	4.57	4.15	8.00	6.00	2.032	24.0	0.0	
26.03.2024	67.21	47.01	20.20	105.53	100.13	0.00	5.25	103.36	99.07	4.24	4.29	8.00	6.00	2.093	24.0	0.0	
27.03.2024	66.59	47.90	18.69	116.44	110.77	0.00	4.99	114.08	109.56	4.04	4.52	8.00	6.00	2.135	24.0	0.0	
28.03.2024	65.78	46.03	19.75	105.39	100.13	0.00	5.12	103.32	99.13	4.14	4.19	8.00	6.00	2.045	24.0	0.0	
29.03.2024	65.90	44.32	21.58	94.98	90.10	0.00	5.27	93.13	89.27	4.23	3.86	8.00	6.00	2.010	24.0	0.0	
30.03.2024	66.25	45.84	20.41	103.33	98.28	0.00	5.01	101.28	97.31	4.00	3.97	8.00	6.00	2.070	24.0	0.0	
31.03.2024	66.20	46.50	19.70	106.25	101.16	0.00	4.91	104.16	100.14	3.94	4.02	8.00	6.00	2.053	24.0	0.0	
Средние:	67.88	46.01	21.87	---	---	---	5.77	---	---	---	---	8.00	6.00	---	---	---	
Итого:	---	---	---	3113.93	2941.08	0.00	---	3049.36	2911.00	---	138.36	---	---	65.950	744.0	0.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	Т	Т	Т	Гкал	ч	ч
29.02.2024	66804.28	66244.91	0.00	65176.29	65204.07	-27.78	1045.699	14025.0	0.0
31.03.2024	69918.21	69185.99	0.00	68225.65	68115.07	110.58	1111.649	14769.0	0.0
Итого:	3113.93	2941.08	0.00	3049.36	2911.00	138.36	65.950	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, Баранчинская ул, д. 2 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 00123848

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система теплоснабжения, измерение расхода в трех трубопроводах (Схема 1)

Дата	t1	t2	dt	V1	V2	V3	M1	M2	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3	м3	т	т	т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2024	69.58	48.85	20.73	116.97	110.57	0.00	114.45	109.33	5.12	8.00	6.00	2.375	24.0	0.0	
02.03.2024	69.27	49.21	20.06	119.98	113.59	0.00	117.43	112.32	5.11	8.00	6.00	2.357	24.0	0.0	
03.03.2024	69.67	49.60	20.07	119.62	113.34	0.00	117.01	112.06	4.95	8.00	6.00	2.349	24.0	0.0	
04.03.2024	69.47	49.89	19.58	121.71	115.44	0.00	119.09	114.08	5.01	8.00	6.00	2.334	24.0	0.0	
05.03.2024	69.41	49.65	19.76	119.45	113.32	0.00	116.88	111.97	4.91	8.00	6.00	2.313	24.0	0.0	
06.03.2024	70.73	48.41	22.32	109.71	103.81	0.00	107.26	102.69	4.57	8.00	6.00	2.396	24.0	0.0	
07.03.2024	70.62	48.32	22.30	110.99	105.09	0.00	108.53	103.90	4.63	8.00	6.00	2.423	24.0	0.0	
08.03.2024	68.30	46.35	21.95	101.88	96.31	0.00	99.72	95.33	4.39	8.00	6.00	2.190	24.0	0.0	
09.03.2024	65.02	42.28	22.74	82.39	77.05	0.00	80.78	76.41	4.37	8.00	6.00	1.835	24.0	0.0	
10.03.2024	68.24	42.54	25.70	83.55	77.13	0.00	81.84	76.43	5.41	8.00	6.00	2.104	24.0	0.0	
11.03.2024	66.57	40.21	26.36	52.82	49.79	0.00	51.75	49.39	2.36	8.00	6.00	1.354	24.0	0.0	*
12.03.2024	69.17	41.62	27.55	84.98	78.43	0.00	83.17	77.75	5.42	8.00	6.00	2.291	24.0	0.0	
13.03.2024	69.38	42.56	26.82	83.73	78.33	0.00	81.93	77.61	4.32	8.00	6.00	2.198	24.0	0.0	
14.03.2024	67.64	43.72	23.92	90.42	85.14	0.00	88.55	84.39	4.16	8.00	6.00	2.117	24.0	0.0	
15.03.2024	67.70	44.50	23.20	92.37	86.95	0.00	90.47	86.17	4.30	8.00	6.00	2.099	24.0	0.0	
16.03.2024	67.40	45.96	21.44	101.77	95.85	0.00	99.68	94.93	4.75	8.00	6.00	2.141	24.0	0.0	
17.03.2024	68.04	47.93	20.11	113.53	107.08	0.00	111.19	105.95	5.24	8.00	6.00	2.236	24.0	0.0	
18.03.2024	68.38	47.09	21.29	102.95	96.70	0.00	100.79	95.69	5.10	8.00	6.00	2.147	24.0	0.0	
19.03.2024	67.86	45.18	22.68	93.23	87.67	0.00	91.29	86.82	4.47	8.00	6.00	2.072	24.0	0.0	
20.03.2024	67.58	45.80	21.78	96.39	91.10	0.00	94.42	90.19	4.23	8.00	6.00	2.056	24.0	0.0	
21.03.2024	67.73	46.01	21.72	96.77	91.63	0.00	94.79	90.70	4.09	8.00	6.00	2.059	24.0	0.0	
22.03.2024	67.37	46.26	21.11	98.79	93.66	0.00	96.79	92.70	4.09	8.00	6.00	2.042	24.0	0.0	
23.03.2024	67.00	45.96	21.04	97.84	92.65	0.00	95.89	91.69	4.20	8.00	6.00	2.016	24.0	0.0	
24.03.2024	66.86	45.39	21.47	95.38	90.23	0.00	93.48	89.32	4.16	8.00	6.00	2.008	24.0	0.0	
25.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
30.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
31.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	68.29	45.97	22.32	---	---	---	---	---	---	8.00	6.00	---	---	---	
Итого:	---	---	---	2387.22	2250.86	0.00	2337.18	2227.82	109.36	---	---	51.512	576.0	0.0	

Дата	V1	V2	V3	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	м3	т	т	т	Гкал	ч	ч
29.02.2024	66804.28	66244.91	0.00	65176.29	65204.07	-27.78	1045.699	14025.0	0.0
24.03.2024	69191.50	68495.77	0.00	67513.47	67431.89	81.58	1097.211	14601.0	0.0
Итого:	2387.22	2250.86	0.00	2337.18	2227.82	109.36	51.512	576.0	0.0

Представитель абонента

Представитель энергоснабжающей организации