

Отчет о суточных параметрах
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермский край, Пермь г, Ивана Франко ул, д. 43А (МКД)

Прибор: ТВ7 Заводской номер: 23189335

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	dM	P1	P2	Qтв	ВНР	ВОС	tx	НС
	°C	°C	°C	м3	м3	т	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	°C	
01.03.2024	72.06	48.35	23.71	111.10	110.86	108.53	109.65	-1.03	-1.12	6.12	4.51	2.577	24.0	0.0	0.00	
02.03.2024	71.72	47.23	24.49	104.04	103.79	101.65	102.71	-1.04	-1.06	6.12	4.51	2.493	24.0	0.0	0.00	
03.03.2024	72.16	46.89	25.26	101.55	101.27	99.19	100.23	-1.04	-1.04	6.12	4.51	2.509	24.0	0.0	0.00	
04.03.2024	71.91	47.03	24.88	96.55	96.28	94.33	95.29	-1.02	-0.96	6.12	4.51	2.351	24.0	0.0	0.00	
05.03.2024	72.09	47.67	24.42	103.97	103.72	101.56	102.63	-1.05	-1.07	6.12	4.51	2.484	24.0	0.0	0.00	
06.03.2024	74.09	49.77	24.32	123.52	123.19	120.51	121.76	-1.03	-1.25	6.12	4.51	2.936	24.0	0.0	0.00	
07.03.2024	73.95	49.93	24.02	125.11	124.76	122.06	123.31	-1.02	-1.25	6.12	4.51	2.937	24.0	0.0	0.00	
08.03.2024	72.23	49.16	23.07	121.11	120.81	118.30	119.44	-0.96	-1.14	6.12	4.51	2.733	24.0	0.0	0.00	
09.03.2024	72.22	48.94	23.28	121.93	121.57	119.10	120.22	-0.93	-1.12	6.12	4.51	2.777	24.0	0.0	0.00	
10.03.2024	73.32	48.90	24.41	125.03	124.41	122.04	123.03	-0.81	-0.99	6.12	4.51	2.984	24.0	0.0	0.00	
11.03.2024	69.79	47.06	22.73	120.69	119.83	117.99	118.57	-0.49	-0.58	6.12	4.51	2.686	24.0	0.0	0.00	
12.03.2024	74.44	49.83	24.61	123.10	122.36	120.07	120.94	-0.72	-0.87	6.12	4.51	2.960	24.0	0.0	0.00	
13.03.2024	74.12	49.61	24.51	124.10	123.59	121.08	122.17	-0.90	-1.10	6.12	4.51	2.972	24.0	0.0	0.00	
14.03.2024	71.53	47.96	23.57	107.52	107.23	105.06	106.08	-0.97	-1.02	6.12	4.51	2.480	24.0	0.0	0.00	
15.03.2024	71.25	47.06	24.19	101.78	101.50	99.47	100.45	-0.98	-0.98	6.12	4.51	2.410	24.0	0.0	0.00	
16.03.2024	71.06	46.63	24.43	100.47	100.10	98.20	99.10	-0.91	-0.90	6.12	4.51	2.403	24.0	0.0	0.00	
17.03.2024	70.94	46.82	24.12	101.06	100.76	98.78	99.73	-0.96	-0.96	6.12	4.51	2.386	24.0	0.0	0.00	
18.03.2024	71.57	46.70	24.87	91.58	91.21	89.48	90.29	-0.91	-0.82	6.12	4.51	2.228	24.0	0.0	0.00	
19.03.2024	71.90	48.19	23.71	105.27	105.02	102.83	103.87	-1.01	-1.04	6.12	4.51	2.442	24.0	0.0	0.00	
20.03.2024	71.35	47.40	23.95	99.94	99.78	97.67	98.74	-1.09	-1.07	6.12	4.51	2.343	24.0	0.0	0.00	
21.03.2024	71.38	46.94	24.44	93.55	93.44	91.42	92.48	-1.16	-1.07	6.12	4.51	2.238	24.0	0.0	0.00	
22.03.2024	70.89	46.59	24.30	90.44	90.36	88.40	89.45	-1.17	-1.04	6.12	4.51	2.151	24.0	0.0	0.00	
23.03.2024	70.48	46.64	23.84	91.64	91.63	89.60	90.71	-1.23	-1.11	6.12	4.51	2.139	24.0	0.0	0.00	
24.03.2024	70.62	46.76	23.86	101.86	101.83	99.58	100.80	-1.22	-1.22	6.12	4.51	2.380	24.0	0.0	0.00	
25.03.2024	70.61	46.63	23.99	90.44	90.44	88.42	89.53	-1.24	-1.11	6.12	4.51	2.124	24.0	0.0	0.00	
26.03.2024	70.18	46.41	23.77	86.45	86.50	84.53	85.63	-1.29	-1.10	6.12	4.51	2.012	24.0	0.0	0.00	
27.03.2024	70.08	46.80	23.28	99.70	99.61	97.50	98.59	-1.11	-1.09	6.12	4.51	2.273	24.0	0.0	0.00	
28.03.2024	69.58	48.09	21.49	120.22	120.38	117.60	119.08	-1.25	-1.48	6.12	4.51	2.532	24.0	0.0	0.00	
29.03.2024	69.64	48.49	21.16	117.56	117.76	114.99	116.47	-1.28	-1.48	6.12	4.51	2.437	24.0	0.0	0.00	
30.03.2024	69.77	47.34	22.43	110.23	110.38	107.82	109.24	-1.30	-1.41	6.12	4.51	2.423	24.0	0.0	0.00	
31.03.2024	69.70	46.65	23.05	102.53	102.68	100.29	101.64	-1.33	-1.35	6.12	4.51	2.315	24.0	0.0	0.00	
Средние:	71.50	47.69	23.81	---	---	---	---	-1.05	---	6.12	4.51	---	---	---	0.00	
Итого:	---	---	---	3314.02	3307.04	3238.05	3271.85	---	-33.80	---	---	77.117	744.0	0.0	---	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
29.02.2024	14507.60	14281.61	14120.19	14109.80	10.39	382.664	0.000	0.000	3201.0	318.0
31.03.2024	17821.62	17588.65	17358.24	17381.65	-23.41	459.781	0.000	0.000	3945.0	318.0
Итого:	3314.02	3307.04	3238.05	3271.85	-33.80	77.117	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации