

Отчет о суточных параметрах
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, КИМ ул, д. 17 (Население ВК-2 (ООО УК "КОД"))
Прибор: ТВ7 Заводской номер: 20139946
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

| Дата | t1 °C | t2 °C | dt °C | V1 м3 | V2 м3 | M1 т | M2 т | % т | dM т | P1 кгс/см2 | P2 кгс/см2 | Qтв ГКал | ВНР ч | ВОС ч | tx °C | НС |
|------------|----------|----------|----------|----------|----------|----------|----------|--------|---------|---------------|---------------|-------------|----------|----------|----------|----|
| 01.03.2024 | 57.21 | 49.06 | 8.15 | 592.55 | 593.45 | 583.49 | 586.81 | -0.57 | -3.33 | 0.46 | 4.24 | 4.713 | 24.0 | 0.0 | 0.00 | |
| 02.03.2024 | 56.70 | 48.83 | 7.87 | 602.34 | 603.33 | 593.25 | 596.64 | -0.57 | -3.39 | 0.45 | 4.08 | 4.625 | 24.0 | 0.0 | 0.00 | |
| 03.03.2024 | 55.69 | 48.10 | 7.59 | 600.59 | 601.62 | 591.87 | 595.15 | -0.55 | -3.29 | 0.44 | 4.13 | 4.447 | 24.0 | 0.0 | 0.00 | |
| 04.03.2024 | 55.76 | 48.20 | 7.56 | 598.37 | 599.46 | 589.66 | 593.00 | -0.57 | -3.34 | 0.45 | 4.14 | 4.415 | 24.0 | 0.0 | 0.00 | |
| 05.03.2024 | 55.77 | 48.19 | 7.57 | 596.57 | 597.65 | 587.89 | 591.20 | -0.56 | -3.31 | 0.45 | 4.09 | 4.407 | 24.0 | 0.0 | 0.00 | |
| 06.03.2024 | 63.88 | 53.85 | 10.03 | 595.32 | 595.89 | 584.09 | 587.84 | -0.64 | -3.75 | 0.53 | 4.28 | 5.816 | 24.0 | 0.0 | 0.00 | |
| 07.03.2024 | 65.12 | 54.91 | 10.20 | 594.06 | 594.90 | 582.47 | 586.57 | -0.70 | -4.11 | 0.54 | 3.79 | 5.908 | 24.0 | 0.0 | 0.00 | |
| 08.03.2024 | 60.16 | 51.39 | 8.78 | 593.52 | 594.73 | 583.50 | 587.44 | -0.67 | -3.94 | 0.50 | 3.76 | 5.083 | 24.0 | 0.0 | 0.00 | |
| 09.03.2024 | 58.85 | 50.38 | 8.46 | 593.01 | 594.25 | 583.43 | 587.27 | -0.66 | -3.84 | 0.48 | 3.89 | 4.899 | 24.0 | 0.0 | 0.00 | |
| 10.03.2024 | 65.34 | 54.95 | 10.39 | 593.64 | 594.32 | 581.97 | 585.97 | -0.69 | -4.00 | 0.55 | 3.77 | 6.013 | 24.0 | 0.0 | 0.00 | |
| 11.03.2024 | 68.20 | 57.07 | 11.14 | 594.28 | 595.02 | 581.70 | 586.04 | -0.74 | -4.34 | 0.57 | 3.70 | 6.447 | 24.0 | 0.0 | 0.00 | |
| 12.03.2024 | 66.81 | 56.14 | 10.67 | 593.44 | 594.43 | 581.32 | 585.74 | -0.76 | -4.42 | 0.55 | 3.77 | 6.167 | 24.0 | 0.0 | 0.00 | |
| 13.03.2024 | 63.33 | 53.63 | 9.69 | 592.50 | 593.71 | 581.54 | 585.79 | -0.73 | -4.24 | 0.50 | 3.88 | 5.601 | 24.0 | 0.0 | 0.00 | |
| 14.03.2024 | 56.50 | 48.66 | 7.84 | 584.58 | 585.82 | 575.81 | 579.33 | -0.61 | -3.52 | 0.43 | 3.62 | 4.476 | 24.0 | 0.0 | 0.00 | |
| 15.03.2024 | 54.65 | 47.26 | 7.39 | 586.09 | 587.31 | 577.85 | 581.22 | -0.58 | -3.37 | 0.41 | 3.71 | 4.231 | 24.0 | 0.0 | 0.00 | |
| 16.03.2024 | 53.67 | 46.47 | 7.20 | 574.84 | 576.54 | 567.05 | 570.76 | -0.65 | -3.70 | 0.39 | 3.47 | 4.044 | 24.0 | 0.0 | 0.00 | |
| 17.03.2024 | 52.38 | 45.34 | 7.04 | 553.30 | 556.17 | 546.15 | 550.89 | -0.86 | -4.74 | 0.37 | 3.34 | 3.808 | 24.0 | 0.0 | 0.00 | |
| 18.03.2024 | 51.23 | 44.06 | 7.18 | 498.84 | 500.69 | 492.63 | 496.21 | -0.72 | -3.58 | 0.37 | 3.67 | 3.500 | 24.0 | 0.0 | 0.00 | |
| 19.03.2024 | 52.52 | 45.40 | 7.12 | 552.26 | 554.19 | 545.07 | 548.92 | -0.70 | -3.86 | 0.38 | 4.42 | 3.832 | 24.0 | 0.0 | 0.00 | |
| 20.03.2024 | 49.35 | 43.38 | 5.97 | 574.34 | 576.30 | 567.75 | 571.37 | -0.64 | -3.62 | 0.36 | 4.83 | 3.338 | 24.0 | 0.0 | 0.00 | |
| 21.03.2024 | 45.43 | 40.27 | 5.16 | 545.39 | 547.13 | 540.07 | 543.11 | -0.56 | -3.04 | 0.34 | 4.67 | 2.737 | 24.0 | 0.0 | 0.00 | |
| 22.03.2024 | 47.56 | 41.95 | 5.61 | 577.55 | 579.42 | 571.37 | 574.80 | -0.60 | -3.44 | 0.37 | 5.03 | 3.147 | 24.0 | 0.0 | 0.00 | |
| 23.03.2024 | 48.63 | 42.86 | 5.77 | 576.98 | 578.87 | 570.59 | 574.04 | -0.60 | -3.46 | 0.39 | 5.23 | 3.232 | 24.0 | 0.0 | 0.00 | |
| 24.03.2024 | 48.17 | 42.50 | 5.67 | 575.85 | 577.82 | 569.54 | 573.07 | -0.62 | -3.54 | 0.39 | 5.23 | 3.173 | 24.0 | 0.0 | 0.00 | |
| 25.03.2024 | 48.67 | 42.81 | 5.86 | 566.61 | 569.19 | 560.29 | 564.42 | -0.73 | -4.13 | 0.39 | 4.59 | 3.233 | 24.0 | 0.0 | 0.00 | |
| 26.03.2024 | 48.66 | 42.77 | 5.89 | 557.44 | 560.43 | 551.21 | 555.71 | -0.81 | -4.50 | 0.39 | 4.14 | 3.201 | 24.0 | 0.0 | 0.00 | |
| 27.03.2024 | 48.37 | 42.52 | 5.85 | 562.94 | 565.14 | 556.75 | 560.46 | -0.66 | -3.71 | 0.40 | 4.46 | 3.207 | 24.0 | 0.0 | 0.00 | |
| 28.03.2024 | 50.59 | 44.08 | 6.50 | 573.00 | 574.69 | 566.10 | 569.57 | -0.61 | -3.47 | 0.42 | 4.86 | 3.629 | 24.0 | 0.0 | 0.00 | |
| 29.03.2024 | 52.10 | 45.14 | 6.96 | 573.07 | 574.67 | 565.76 | 569.32 | -0.63 | -3.56 | 0.43 | 4.85 | 3.885 | 24.0 | 0.0 | 0.00 | |
| 30.03.2024 | 48.33 | 42.43 | 5.90 | 571.66 | 573.75 | 565.35 | 569.04 | -0.65 | -3.69 | 0.41 | 4.80 | 3.280 | 24.0 | 0.0 | 0.00 | |
| 31.03.2024 | 48.00 | 42.19 | 5.81 | 571.37 | 573.51 | 565.15 | 568.86 | -0.65 | -3.71 | 0.40 | 4.86 | 3.232 | 24.0 | 0.0 | 0.00 | |
| Средние: | 54.76 | 47.25 | 7.51 | --- | --- | --- | --- | -0.66 | --- | 0.44 | 4.24 | --- | --- | --- | 0.00 | |
| Итого: | --- | --- | --- | 17916.28 | 17964.39 | 17660.63 | 17776.57 | --- | -115.94 | --- | --- | 131.729 | 744.0 | 0.0 | --- | |

| Дата | V1 м3 | V2 м3 | M1 т | M2 т | dM т | Qтв ГКал | Q12 ГКал | Qг ГКал | ВНР ч | ВОС ч |
|------------|-----------|-----------|-----------|-----------|---------|-------------|-------------|------------|----------|----------|
| 29.02.2024 | 218734.48 | 221267.30 | 214726.52 | 213778.29 | 948.23 | 1806.170 | 0.000 | 0.000 | 13078.0 | 1233.0 |
| 31.03.2024 | 236650.76 | 239231.69 | 232387.16 | 231554.86 | 832.30 | 1937.899 | 0.000 | 0.000 | 13822.0 | 1233.0 |
| Итого: | 17916.28 | 17964.39 | 17660.63 | 17776.57 | -115.94 | 131.729 | 0.000 | 0.000 | 744.0 | 0.0 |

Представитель абонента

Представитель энергоснабжающей организации