

Отчет о суточных параметрах  
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермский край, Пермь г, Хрустальная ул, д. 30 (ООО УК "КОД")  
Прибор: ТВ7 Заводской номер: 20137965  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1 °C	t2 °C	dt °C	V1 м3	V2 м3	M1 т	M2 т	% т	dM т	P1 кгс/см2	P2 кгс/см2	Qтв ГКал	ВНР ч	ВОС ч	tx °C	НС
01.03.2024	56.77	46.14	10.63	414.85	411.16	408.68	407.13	0.38	1.56	5.07	4.71	4.346	24.0	0.0	0.00	
02.03.2024	56.28	46.04	10.24	421.75	418.10	415.56	414.01	0.38	1.56	4.91	4.54	4.257	24.0	0.0	0.00	
03.03.2024	55.26	45.42	9.84	420.66	417.08	414.72	413.14	0.38	1.57	4.97	4.61	4.083	24.0	0.0	0.00	
04.03.2024	55.33	45.52	9.81	419.11	415.58	413.18	411.62	0.38	1.56	4.97	4.61	4.055	24.0	0.0	0.00	
05.03.2024	55.35	45.56	9.79	417.98	414.47	412.07	410.49	0.38	1.57	4.93	4.57	4.036	24.0	0.0	0.00	
06.03.2024	63.44	50.47	12.97	416.65	412.55	408.99	407.70	0.32	1.29	5.12	4.76	5.308	24.0	0.0	0.00	
07.03.2024	64.56	51.44	13.12	416.32	412.18	408.43	407.12	0.32	1.31	4.62	4.26	5.361	24.0	0.0	0.00	
08.03.2024	59.66	48.37	11.29	415.65	411.92	408.83	407.46	0.34	1.38	4.59	4.24	4.618	24.0	0.0	0.00	
09.03.2024	58.42	47.45	10.97	415.24	411.58	408.70	407.31	0.34	1.40	4.72	4.37	4.487	24.0	0.0	0.00	
10.03.2024	64.89	51.44	13.45	415.33	411.14	407.36	406.10	0.31	1.26	4.60	4.25	5.482	24.0	0.0	0.00	
11.03.2024	67.64	53.29	14.35	415.32	410.89	406.70	405.48	0.30	1.22	4.52	4.18	5.839	24.0	0.0	0.00	
12.03.2024	66.27	52.48	13.80	414.80	410.54	406.54	405.32	0.30	1.23	4.59	4.25	5.613	24.0	0.0	0.00	
13.03.2024	62.78	50.19	12.59	414.37	410.39	406.90	405.57	0.33	1.33	4.70	4.36	5.127	24.0	0.0	0.00	
14.03.2024	56.01	45.83	10.17	408.25	404.20	402.31	400.28	0.51	2.03	4.46	4.11	4.094	24.0	0.0	0.00	
15.03.2024	54.22	44.58	9.65	409.80	405.65	404.21	401.94	0.56	2.28	4.54	4.19	3.900	24.0	0.0	0.00	
16.03.2024	53.23	43.93	9.30	405.60	401.66	400.26	398.09	0.54	2.17	4.32	3.95	3.723	24.0	0.0	0.00	
17.03.2024	52.01	43.36	8.65	411.74	408.85	406.55	405.33	0.30	1.23	4.19	3.76	3.517	24.0	0.0	0.00	
18.03.2024	50.91	42.89	8.02	422.31	419.30	417.23	415.77	0.35	1.45	4.52	4.07	3.350	24.0	0.0	0.00	
19.03.2024	52.14	43.36	8.78	407.47	404.28	402.35	400.83	0.38	1.52	5.22	4.83	3.534	24.0	0.0	0.00	
20.03.2024	48.96	41.30	7.67	404.02	400.54	399.57	397.46	0.53	2.11	5.67	5.31	3.063	24.0	0.0	0.00	
21.03.2024	45.07	38.58	6.48	383.14	380.06	379.56	377.54	0.53	2.02	5.51	5.15	2.461	24.0	0.0	0.00	
22.03.2024	47.28	40.11	7.18	401.01	397.54	396.90	394.68	0.56	2.22	5.89	5.52	2.848	24.0	0.0	0.00	
23.03.2024	48.27	40.75	7.52	402.12	398.67	397.81	395.71	0.53	2.11	6.07	5.72	2.990	24.0	0.0	0.00	
24.03.2024	47.81	40.36	7.45	401.27	397.98	397.04	395.06	0.50	1.97	6.07	5.72	2.956	24.0	0.0	0.00	
25.03.2024	48.33	40.60	7.73	397.63	394.62	393.35	391.69	0.42	1.65	5.42	5.07	3.041	24.0	0.0	0.00	
26.03.2024	48.30	40.61	7.69	393.48	390.66	389.23	387.75	0.38	1.48	4.97	4.62	2.992	24.0	0.0	0.00	
27.03.2024	47.95	40.42	7.53	396.20	392.67	392.00	389.78	0.57	2.22	5.31	4.96	2.952	24.0	0.0	0.00	
28.03.2024	50.22	41.76	8.46	399.39	396.00	394.73	392.88	0.47	1.85	5.70	5.36	3.340	24.0	0.0	0.00	
29.03.2024	51.70	42.77	8.93	399.34	396.08	394.39	392.78	0.41	1.61	5.68	5.34	3.521	24.0	0.0	0.00	
30.03.2024	47.94	40.36	7.57	398.72	395.63	394.51	392.74	0.45	1.77	5.64	5.30	2.988	24.0	0.0	0.00	
31.03.2024	47.66	40.13	7.52	398.53	395.21	394.35	392.36	0.51	2.00	5.70	5.36	2.967	24.0	0.0	0.00	
Средние:	54.34	44.69	9.65	---	---	---	---	0.42	---	5.07	4.71	---	---	---	0.00	
Итого:	---	---	---	12658.03	12547.19	12483.01	12431.10	---	51.91	---	---	120.850	744.0	0.0	---	

Дата	V1 м3	V2 м3	M1 т	M2 т	dM т	Qтв ГКал	Q12 ГКал	Qг ГКал	ВНР ч	ВОС ч
29.02.2024	164697.10	162374.93	160274.12	158863.19	1410.94	1721.636	0.000	0.000	13109.0	171.0
31.03.2024	177355.13	174922.13	172757.13	171294.28	1462.85	1842.486	0.000	0.000	13853.0	171.0
Итого:	12658.03	12547.19	12483.01	12431.10	51.91	120.850	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации