

Отчет о суточных параметрах
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермский край, Пермь г, Целинная ул, д. 31/1 (Жилой дом)

Прибор: ВКТ-7 Заводской номер: 00157940

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2024	68.62	49.80	18.82	223.91	221.19	1.22	219.17	218.62	0.25	0.55	7.00	6.00	4.124	24.0	0.0	
02.03.2024	68.19	47.79	20.40	191.39	188.95	1.28	187.40	186.93	0.25	0.47	7.00	6.00	3.823	24.0	0.0	
03.03.2024	68.20	47.55	20.65	185.41	183.02	1.30	181.56	181.11	0.25	0.45	7.00	6.00	3.749	24.0	0.0	
04.03.2024	68.26	47.71	20.55	186.83	184.48	1.27	182.95	182.53	0.23	0.42	7.00	6.00	3.759	24.0	0.0	
05.03.2024	68.46	47.99	20.47	188.95	186.57	1.27	185.01	184.57	0.24	0.44	7.00	6.00	3.786	24.0	0.0	
06.03.2024	70.00	48.54	21.46	192.04	189.41	1.38	187.82	187.31	0.27	0.51	7.00	6.00	4.030	24.0	0.0	
07.03.2024	69.72	48.81	20.91	200.68	198.02	1.33	196.31	195.84	0.24	0.47	7.00	6.00	4.106	24.0	0.0	
08.03.2024	68.07	49.78	18.29	232.86	230.27	1.12	228.01	227.57	0.19	0.44	7.00	6.00	4.169	24.0	0.0	
09.03.2024	68.36	49.83	18.53	225.62	223.06	1.14	220.86	220.48	0.17	0.38	7.00	6.00	4.091	24.0	0.0	
10.03.2024	68.95	48.49	20.46	197.66	195.16	1.27	193.46	192.99	0.24	0.47	7.00	6.00	3.957	24.0	0.0	
11.03.2024	65.99	46.66	19.33	197.14	194.78	1.20	193.16	192.74	0.22	0.42	7.00	6.00	3.722	24.0	0.0	
12.03.2024	71.18	51.95	19.23	250.64	247.62	1.21	245.00	244.50	0.20	0.50	7.00	6.00	4.713	24.0	0.0	
13.03.2024	70.61	51.96	18.65	254.90	251.88	1.19	249.26	248.70	0.22	0.56	7.00	6.00	4.651	24.0	0.0	
14.03.2024	68.06	49.66	18.40	213.29	210.91	1.12	208.84	208.47	0.18	0.37	7.00	6.00	3.845	24.0	0.0	
15.03.2024	67.70	45.84	21.86	149.78	147.80	1.33	146.68	146.36	0.22	0.32	7.00	6.00	3.207	24.0	0.0	
16.03.2024	67.68	44.67	23.01	131.82	129.98	1.41	129.07	128.77	0.23	0.30	7.00	6.00	2.968	24.0	0.0	
17.03.2024	67.56	44.98	22.58	133.45	131.64	1.37	130.70	130.38	0.25	0.32	7.00	6.00	2.951	24.0	0.0	
18.03.2024	67.84	44.01	23.83	124.33	122.53	1.46	121.75	121.42	0.27	0.33	7.00	6.00	2.901	24.0	0.0	
19.03.2024	68.41	48.73	19.68	187.31	185.10	1.19	183.37	183.04	0.18	0.33	7.00	6.00	3.611	24.0	0.0	
20.03.2024	67.69	45.55	22.14	135.94	134.10	1.36	133.13	132.79	0.26	0.34	7.00	6.00	2.947	24.0	0.0	
21.03.2024	67.66	43.28	24.38	107.81	106.20	1.50	105.58	105.25	0.31	0.33	7.00	6.00	2.572	24.0	0.0	
22.03.2024	66.90	39.07	27.83	78.45	77.10	1.74	76.86	76.56	0.39	0.30	7.00	6.00	2.136	24.0	0.0	
23.03.2024	66.43	38.97	27.46	79.19	77.86	1.69	77.60	77.30	0.39	0.30	7.00	6.00	2.128	24.0	0.0	
24.03.2024	66.11	39.50	26.61	86.64	85.25	1.62	84.92	84.65	0.32	0.27	7.00	6.00	2.259	24.0	0.0	
25.03.2024	66.39	38.40	27.99	77.43	76.11	1.72	75.89	75.63	0.34	0.26	7.00	6.00	2.122	24.0	0.0	
26.03.2024	65.66	38.63	27.03	81.03	79.70	1.65	79.47	79.15	0.40	0.32	7.00	6.00	2.147	24.0	0.0	
27.03.2024	65.42	39.63	25.79	94.11	92.67	1.54	92.30	92.00	0.33	0.30	7.00	6.00	2.379	24.0	0.0	
28.03.2024	65.72	43.85	21.87	147.62	145.65	1.34	144.75	144.36	0.27	0.39	7.00	6.00	3.164	24.0	0.0	
29.03.2024	65.80	44.29	21.51	154.09	152.07	1.32	151.07	150.68	0.26	0.39	7.00	6.00	3.248	24.0	0.0	
30.03.2024	65.79	41.74	24.05	109.06	107.46	1.48	106.94	106.56	0.36	0.38	7.00	6.00	2.572	24.0	0.0	
31.03.2024	64.93	38.62	26.31	85.53	84.20	1.57	83.91	83.63	0.33	0.28	7.00	6.00	2.206	24.0	0.0	
Средние:	67.62	45.36	22.26	---	---	1.37	---	---	0.27	---	7.00	6.00	---	---	---	
Итого:	---	---	---	4904.91	4840.74	---	4802.80	4790.89	---	11.91	---	---	102.043	744.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
29.02.2024	29493.90	29063.14	28777.54	28707.79	69.75	658.241	3874.0	1657.0
31.03.2024	34398.81	33903.88	33580.34	33498.68	81.66	760.284	4618.0	1657.0
Итого:	4904.91	4840.74	4802.80	4790.89	11.91	102.043	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах
(01.03.2024 0:00:00 - 31.03.2024 0:00:00)

Объект: Пермь г, Целинная ул, д. 31/1 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 00157940

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.03.2024	68.62	49.80	18.82	223.91	221.19	1.22	219.17	218.62	0.25	0.55	7.00	6.00	4.124	24.0	0.0	
02.03.2024	68.19	47.79	20.40	191.39	188.95	1.28	187.40	186.93	0.25	0.47	7.00	6.00	3.823	24.0	0.0	
03.03.2024	68.20	47.55	20.65	185.41	183.02	1.30	181.56	181.11	0.25	0.45	7.00	6.00	3.749	24.0	0.0	
04.03.2024	68.26	47.71	20.55	186.83	184.48	1.27	182.95	182.53	0.23	0.42	7.00	6.00	3.759	24.0	0.0	
05.03.2024	68.46	47.99	20.47	188.95	186.57	1.27	185.01	184.57	0.24	0.44	7.00	6.00	3.786	24.0	0.0	
06.03.2024	70.00	48.54	21.46	192.04	189.41	1.38	187.82	187.31	0.27	0.51	7.00	6.00	4.030	24.0	0.0	
07.03.2024	69.72	48.81	20.91	200.68	198.02	1.33	196.31	195.84	0.24	0.47	7.00	6.00	4.106	24.0	0.0	
08.03.2024	68.07	49.78	18.29	232.86	230.27	1.12	228.01	227.57	0.19	0.44	7.00	6.00	4.169	24.0	0.0	
09.03.2024	68.36	49.83	18.53	225.62	223.06	1.14	220.86	220.48	0.17	0.38	7.00	6.00	4.091	24.0	0.0	
10.03.2024	68.95	48.49	20.46	197.66	195.16	1.27	193.46	192.99	0.24	0.47	7.00	6.00	3.957	24.0	0.0	
11.03.2024	65.99	46.66	19.33	197.14	194.78	1.20	193.16	192.74	0.22	0.42	7.00	6.00	3.722	24.0	0.0	
12.03.2024	71.18	51.95	19.23	250.64	247.62	1.21	245.00	244.50	0.20	0.50	7.00	6.00	4.713	24.0	0.0	
13.03.2024	70.61	51.96	18.65	254.90	251.88	1.19	249.26	248.70	0.22	0.56	7.00	6.00	4.651	24.0	0.0	
14.03.2024	68.06	49.66	18.40	213.29	210.91	1.12	208.84	208.47	0.18	0.37	7.00	6.00	3.845	24.0	0.0	
15.03.2024	67.70	45.84	21.86	149.78	147.80	1.33	146.68	146.36	0.22	0.32	7.00	6.00	3.207	24.0	0.0	
16.03.2024	67.68	44.67	23.01	131.82	129.98	1.41	129.07	128.77	0.23	0.30	7.00	6.00	2.968	24.0	0.0	
17.03.2024	67.56	44.98	22.58	133.45	131.64	1.37	130.70	130.38	0.25	0.32	7.00	6.00	2.951	24.0	0.0	
18.03.2024	67.84	44.01	23.83	124.33	122.53	1.46	121.75	121.42	0.27	0.33	7.00	6.00	2.901	24.0	0.0	
19.03.2024	68.41	48.73	19.68	187.31	185.10	1.19	183.37	183.04	0.18	0.33	7.00	6.00	3.611	24.0	0.0	
20.03.2024	67.69	45.55	22.14	135.94	134.10	1.36	133.13	132.79	0.26	0.34	7.00	6.00	2.947	24.0	0.0	
21.03.2024	67.66	43.28	24.38	107.81	106.20	1.50	105.58	105.25	0.31	0.33	7.00	6.00	2.572	24.0	0.0	
22.03.2024	66.90	39.07	27.83	78.45	77.10	1.74	76.86	76.56	0.39	0.30	7.00	6.00	2.136	24.0	0.0	
23.03.2024	66.43	38.97	27.46	79.19	77.86	1.69	77.60	77.30	0.39	0.30	7.00	6.00	2.128	24.0	0.0	
24.03.2024	66.11	39.50	26.61	86.64	85.25	1.62	84.92	84.65	0.32	0.27	7.00	6.00	2.259	24.0	0.0	
25.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
30.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
31.03.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	68.19	46.71	21.48	---	---	1.33	---	---	0.25	---	7.00	6.00	---	---	---	
Итого:	---	---	---	4156.04	4102.88	---	4068.47	4058.88	---	9.59	---	---	84.205	576.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
29.02.2024	29493.90	29063.14	28777.54	28707.79	69.75	658.241	3874.0	1657.0
24.03.2024	33649.94	33166.02	32846.01	32766.67	79.34	742.446	4450.0	1657.0
Итого:	4156.04	4102.88	4068.47	4058.88	9.59	84.205	576.0	0.0

Представитель абонента

Представитель энергоснабжающей организации