

Отчет о суточных параметрах
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермь г, Гашкова ул, д. 41/1 (ООО УК "КОД")
Прибор: ВКТ-7 Заводской номер: 123456
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Открытая система теплоснабжения, измерение расхода в трех трубопроводах (Схема 1)

Дата	t1 °C	t2 °C	dt °C	V1 м3	V2 м3	V3 м3	M1 т	M2 т	Mг т	P1 кг/см2	P2 кг/см2	Qo Гкал	ВНР ч	ВОС ч	НС
01.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
02.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
03.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
04.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
05.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
06.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
07.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
08.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
09.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
10.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
11.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
12.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
13.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
14.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
15.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
16.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
17.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
18.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
19.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
20.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
21.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
22.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
23.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
24.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
25.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
26.09.2024	57.97	34.39	23.58	83.43	83.57	0.00	81.67	82.76	-1.09	---	---	1.864	35.0	0.0	*
27.09.2024	59.87	32.25	27.62	24.71	24.92	0.00	24.30	24.80	-0.50	7.00	5.50	0.671	24.0	0.0	*
28.09.2024	61.90	29.26	32.64	14.02	14.17	0.00	13.79	14.11	-0.32	7.00	5.50	0.449	24.0	0.0	*
29.09.2024	60.68	32.11	28.57	14.21	14.33	0.00	13.99	14.27	-0.28	7.00	5.50	0.400	24.0	0.0	*
30.09.2024	62.97	43.51	19.46	40.31	38.95	0.00	39.60	38.59	1.01	7.00	5.50	0.776	24.0	0.0	*
Средние:	60.68	34.30	26.37	---	---	---	---	---	---	7.00	5.50	---	---	---	---
Итого:	---	---	---	176.68	175.94	0.00	173.35	174.53	-1.18	---	---	4.160	131.0	0.0	---

Дата	V1 м3	V2 м3	V3 м3	M1 т	M2 т	Mг т	Qo Гкал	ВНР ч	ВОС ч
25.09.2024	0.00	0.00	0.00	0.00	0.00	0.00	0.000	34.4	0.0
30.09.2024	176.68	175.94	0.00	173.35	174.53	-1.18	4.160	131.0	0.0
Итого:	176.68	175.94	0.00	173.35	174.53	-1.18	4.160	96.6	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермь г, Гашкова ул, д. 41/1 (ООО УК "КОД")
Прибор: ВКТ-7 Заводской номер: 123456
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1 °C	t2 °C	dt	V1 м3	V2 м3	M1 т	M2 т	Mг т	P1 кг/см2	P2 кг/см2	Qo Гкал	Qg Гкал	tхв °C	ВНР ч	ВОС ч	НС
01.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
02.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
03.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
04.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
05.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
06.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
07.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
08.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
09.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
10.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
11.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
12.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
13.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
14.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
15.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
16.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
17.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
18.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
19.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
20.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
21.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
22.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
23.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
24.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
25.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
26.09.2024	0.06	48.57	-48.51	12.42	12.71	12.22	12.60	-0.38	---	---	0.049	-0.012	5.00	35.0	0.0	---
27.09.2024	54.65	49.03	5.62	27.78	29.71	27.34	29.43	-2.09	6.50	5.50	0.070	-0.072	5.00	24.0	0.0	---
28.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
29.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
30.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Средние:	27.36	48.80	-21.45	---	---	---	---	---	6.50	5.50	---	---	5.00	---	---	---
Итого:	---	---	---	40.20	42.42	39.56	42.03	-2.47	---	---	0.119	-0.084	---	59.0	0.0	---

Дата	V1 м3	V2 м3	M1 т	M2 т	Mг т	Qo Гкал	Qg Гкал	ВНР ч	ВОС ч
25.09.2024	0.00	0.00	0.00	0.00	0.00	0.000	0.000	34.4	0.0
27.09.2024	40.20	42.42	39.56	42.03	-2.47	0.119	-0.084	59.0	0.0
Итого:	40.20	42.42	39.56	42.03	-2.47	0.119	-0.084	24.6	0.0

Представитель абонента

Представитель энергоснабжающей организации