

Отчет о суточных параметрах  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермь г, Гашкова ул, д. 41 (ООО УК "КОД")  
Прибор: ВКТ-7 Заводской номер: 00143494  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2024	21.97	21.00	0.97	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
02.09.2024	21.83	20.96	0.87	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
03.09.2024	21.87	20.98	0.89	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
04.09.2024	21.88	20.94	0.94	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
05.09.2024	21.75	20.87	0.88	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
06.09.2024	21.34	20.52	0.82	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
07.09.2024	21.41	20.69	0.72	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
08.09.2024	21.85	21.05	0.80	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
09.09.2024	22.16	21.37	0.79	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
10.09.2024	22.34	21.57	0.77	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
11.09.2024	22.30	21.50	0.80	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
12.09.2024	22.14	21.30	0.84	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
13.09.2024	22.27	21.47	0.80	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
14.09.2024	22.31	21.56	0.75	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
15.09.2024	22.41	21.66	0.75	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
16.09.2024	22.56	21.80	0.76	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
17.09.2024	22.64	21.85	0.79	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
18.09.2024	22.62	21.83	0.79	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
19.09.2024	22.66	21.89	0.77	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
20.09.2024	22.54	21.71	0.83	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
21.09.2024	22.21	21.35	0.86	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
22.09.2024	21.55	20.63	0.92	0.00	0.00	---	0.00	0.00	---	0.00	6.00	4.00	0.000	24.0	0.0	*
23.09.2024	66.74	32.65	34.09	6.70	6.94	-3.52	6.59	6.94	-5.17	-0.35	6.00	4.00	0.220	24.0	0.0	*
24.09.2024	67.36	44.01	23.35	29.54	29.45	0.31	28.97	29.24	-0.93	-0.27	6.00	4.00	0.678	24.0	0.0	
25.09.2024	62.71	39.07	23.64	29.38	29.33	0.17	28.84	29.08	-0.83	-0.24	6.00	4.00	0.680	24.0	0.0	
26.09.2024	58.62	35.43	23.19	23.95	23.98	-0.13	23.60	23.76	-0.68	-0.16	6.00	4.00	0.546	24.0	0.0	
27.09.2024	60.63	39.23	21.40	30.28	30.28	0.00	29.73	30.04	-1.04	-0.31	6.00	4.00	0.639	24.0	0.0	
28.09.2024	61.86	40.08	21.78	30.59	30.60	-0.03	30.03	30.36	-1.09	-0.33	6.00	4.00	0.653	24.0	0.0	
29.09.2024	60.82	37.38	23.44	24.17	24.20	-0.12	23.72	23.98	-1.09	-0.26	6.00	4.00	0.554	24.0	0.0	
30.09.2024	61.92	43.57	18.35	34.13	33.97	0.47	33.54	33.63	-0.27	-0.09	6.00	4.00	0.615	24.0	0.0	
Средние:	32.91	26.00	6.91	---	---	-0.10	---	---	-0.37	---	6.00	4.00	---	---	---	
Итого:	---	---	---	208.74	208.75	---	205.02	207.03	---	-2.01	---	---	4.585	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.08.2024	18015.21	17805.68	17594.83	17541.04	53.79	300.929	8255.0	14.0
30.09.2024	18223.95	18014.43	17799.85	17748.07	51.78	305.514	8975.0	14.0
Итого:	208.74	208.75	205.02	207.03	-2.01	4.585	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации