

Отчет о суточных параметрах  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Евгения Пермяка ул, д. 1/3 (МКД)  
Прибор: ВКТ-7 -03 Заводской номер: 00137634  
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2024	21.01	20.97	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
02.09.2024	21.11	21.07	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
03.09.2024	21.33	21.30	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
04.09.2024	21.16	21.13	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
05.09.2024	21.23	21.19	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
06.09.2024	21.16	21.14	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
07.09.2024	21.57	21.54	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
08.09.2024	21.93	21.91	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
09.09.2024	22.35	22.32	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
10.09.2024	22.64	22.59	0.05	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
11.09.2024	22.33	22.29	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
12.09.2024	21.82	21.72	0.10	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
13.09.2024	22.27	22.23	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
14.09.2024	22.58	22.56	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
15.09.2024	22.66	22.61	0.05	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
16.09.2024	22.74	22.70	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
17.09.2024	22.91	22.90	0.01	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
18.09.2024	22.79	20.70	2.09	0.00	1.37	-200.00	0.00	1.37	-200.00	-1.37	7.00	7.00	0.000	24.0	0.0	*
19.09.2024	22.78	22.03	0.75	0.00	1.47	-200.00	0.00	1.47	-200.00	-1.47	7.00	7.00	0.000	24.0	0.0	*
20.09.2024	22.40	21.76	0.64	0.00	1.03	-200.00	0.00	1.03	-200.00	-1.03	7.00	7.00	0.000	24.0	0.0	*
21.09.2024	21.35	20.84	0.51	0.00	0.56	-200.00	0.00	0.56	-200.00	-0.56	7.00	7.00	0.000	24.0	0.0	*
22.09.2024	20.90	20.38	0.52	0.00	0.67	-200.00	0.00	0.67	-200.00	-0.67	7.00	7.00	0.000	24.0	0.0	*
23.09.2024	47.48	42.30	5.18	55.06	54.93	0.24	54.45	54.44	0.02	0.01	7.00	7.00	0.273	24.0	0.0	*
24.09.2024	48.66	45.46	3.20	85.29	84.57	0.85	84.31	83.76	0.65	0.55	7.00	7.00	0.276	24.0	0.0	
25.09.2024	42.40	44.42	-2.02	76.81	76.24	0.74	76.14	75.57	0.75	0.57	7.00	7.00	-0.137	24.0	0.0	
26.09.2024	63.11	56.31	6.80	127.20	122.32	3.91	124.89	120.54	3.54	4.35	7.00	7.00	0.847	24.0	0.0	
27.09.2024	62.43	56.48	5.95	133.54	125.89	5.90	131.13	124.03	5.57	7.10	7.00	7.00	0.780	24.0	0.0	
28.09.2024	62.48	56.61	5.87	132.24	124.61	5.94	129.86	122.74	5.64	7.12	7.00	7.00	0.764	24.0	0.0	
29.09.2024	62.03	55.94	6.09	119.39	111.77	6.59	117.31	110.13	6.31	7.18	7.00	7.00	0.716	24.0	0.0	*
30.09.2024	61.31	53.12	8.19	130.21	124.07	4.83	127.98	122.45	4.42	5.53	7.00	7.00	1.041	24.0	0.0	*
Средние:	31.10	29.62	1.48	---	---	-32.37	---	---	-32.44	---	7.00	7.00	---	---	---	
Итого:	---	---	---	859.74	829.50	---	846.07	818.76	---	27.31	---	---	4.560	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.08.2024	21350.52	20930.05	20881.73	20716.98	164.75	488.450	8282.0	1427.0
30.09.2024	22210.26	21759.55	21727.80	21535.74	192.06	493.010	9002.0	1427.0
Итого:	859.74	829.50	846.07	818.76	27.31	4.560	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Евгения Пермяка ул, д. 1/3 (МКД)  
Прибор: ВКТ-7 -03 Заводской номер: 00137634  
Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1	t2	dt	V1	V2	M1	M2	Mг	P1	P2	Qo	Qg	tхв	ВНР	ВОС	НС
	°C	°C		м3	м3	т	т	т	кг/см2	кг/см2	Гкал	Гкал	°C	ч	ч	
01.09.2024	0.00	45.11	-45.11	27.62	24.77	27.62	24.53	3.09	7.00	7.00	-1.098	0.131	5.00	24.0	0.0	*
02.09.2024	0.00	46.74	-46.74	26.08	25.16	26.08	24.92	1.16	7.00	7.00	-1.147	0.058	5.00	24.0	0.0	*
03.09.2024	0.00	47.53	-47.53	26.42	25.40	26.42	25.16	1.26	7.00	7.00	-1.175	0.066	5.00	24.0	0.0	*
04.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
05.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
06.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
07.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
08.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
09.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
10.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
11.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
12.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
13.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
14.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
15.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
16.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
17.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
18.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
19.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
20.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
21.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
22.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
23.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
24.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
25.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
30.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	0.00	46.46	-46.46	---	---	---	---	---	7.00	7.00	---	---	5.00	---	---	
Итого:	---	---	---	80.12	75.33	80.12	74.61	5.51	---	---	-3.420	0.255	---	72.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	Qg	ВНР	ВОС
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
31.08.2024	8513.07	7748.78	8399.25	7673.89	725.36	27.642	32.450	8282.0	1427.0
03.09.2024	8593.19	7824.11	8479.37	7748.50	730.87	24.222	32.705	8354.0	1427.0
Итого:	80.12	75.33	80.12	74.61	5.51	-3.420	0.255	72.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермь г, Евгения Пермяка ул, д. 1/3 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 00137634

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		Т	Т		Т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2024	21.01	20.97	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
02.09.2024	21.11	21.07	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
03.09.2024	21.33	21.30	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
04.09.2024	21.16	21.13	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
05.09.2024	21.23	21.19	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
06.09.2024	21.16	21.14	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
07.09.2024	21.57	21.54	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
08.09.2024	21.93	21.91	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
09.09.2024	22.35	22.32	0.03	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
10.09.2024	22.64	22.59	0.05	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
11.09.2024	22.33	22.29	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
12.09.2024	21.82	21.72	0.10	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
13.09.2024	22.27	22.23	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
14.09.2024	22.58	22.56	0.02	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
15.09.2024	22.66	22.61	0.05	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
16.09.2024	22.74	22.70	0.04	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
17.09.2024	22.91	22.90	0.01	0.00	0.00	---	0.00	0.00	---	0.00	7.00	7.00	0.000	24.0	0.0	*
18.09.2024	22.79	20.70	2.09	0.00	1.37	-200.00	0.00	1.37	-200.00	-1.37	7.00	7.00	0.000	24.0	0.0	*
19.09.2024	22.78	22.03	0.75	0.00	1.47	-200.00	0.00	1.47	-200.00	-1.47	7.00	7.00	0.000	24.0	0.0	*
20.09.2024	22.40	21.76	0.64	0.00	1.03	-200.00	0.00	1.03	-200.00	-1.03	7.00	7.00	0.000	24.0	0.0	*
21.09.2024	21.35	20.84	0.51	0.00	0.56	-200.00	0.00	0.56	-200.00	-0.56	7.00	7.00	0.000	24.0	0.0	*
22.09.2024	20.90	20.38	0.52	0.00	0.67	-200.00	0.00	0.67	-200.00	-0.67	7.00	7.00	0.000	24.0	0.0	*
23.09.2024	47.48	42.30	5.18	55.06	54.93	0.24	54.45	54.44	0.02	0.01	7.00	7.00	0.273	24.0	0.0	*
24.09.2024	48.66	45.46	3.20	85.29	84.57	0.85	84.31	83.76	0.65	0.55	7.00	7.00	0.276	24.0	0.0	
25.09.2024	42.40	44.42	-2.02	76.81	76.24	0.74	76.14	75.57	0.75	0.57	7.00	7.00	-0.137	24.0	0.0	
26.09.2024	63.11	56.31	6.80	127.20	122.32	3.91	124.89	120.54	3.54	4.35	7.00	7.00	0.847	24.0	0.0	
27.09.2024	62.43	56.48	5.95	133.54	125.89	5.90	131.13	124.03	5.57	7.10	7.00	7.00	0.780	24.0	0.0	
28.09.2024	62.48	56.61	5.87	132.24	124.61	5.94	129.86	122.74	5.64	7.12	7.00	7.00	0.764	24.0	0.0	
29.09.2024	62.03	55.94	6.09	119.39	111.77	6.59	117.31	110.13	6.31	7.18	7.00	7.00	0.716	24.0	0.0	*
30.09.2024	61.31	53.12	8.19	130.21	124.07	4.83	127.98	122.45	4.42	5.53	7.00	7.00	1.041	24.0	0.0	*
Средние:	31.10	29.62	1.48	---	---	-32.37	---	---	-32.44	---	7.00	7.00	---	---	---	
Итого:	---	---	---	859.74	829.50	---	846.07	818.76	---	27.31	---	---	4.560	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	Т	Т	Т	Гкал	ч	ч
31.08.2024	21350.52	20930.05	20881.73	20716.98	164.75	488.450	8282.0	1427.0
30.09.2024	22210.26	21759.55	21727.80	21535.74	192.06	493.010	9002.0	1427.0
Итого:	859.74	829.50	846.07	818.76	27.31	4.560	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермь г, Евгения Пермяка ул, д. 1/3 (ООО УК "КОД")

Прибор: ВКТ-7 Заводской номер: 00137634

Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	t1	t2	dt	V1	V2	M1	M2	Mг	P1	P2	Qo	Qg	tхв	ВНР	ВОС	НС
	°C	°C		м3	м3	т	т	т	кг/см2	кг/см2	Гкал	Гкал	°C	ч	ч	
01.09.2024	0.00	45.11	-45.11	27.62	24.77	27.62	24.53	3.09	7.00	7.00	-1.098	0.131	5.00	24.0	0.0	*
02.09.2024	0.00	46.74	-46.74	26.08	25.16	26.08	24.92	1.16	7.00	7.00	-1.147	0.058	5.00	24.0	0.0	*
03.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
04.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
05.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
06.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
07.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
08.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
09.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
10.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
11.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
12.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
13.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
14.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
15.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
16.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
17.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
18.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
19.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
20.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
21.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
22.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
23.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
24.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
25.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
26.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
27.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
28.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
29.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
30.09.2024	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	
Средние:	0.00	45.93	-45.93	---	---	---	---	---	7.00	7.00	---	---	5.00	---	---	
Итого:	---	---	---	53.70	49.93	53.70	49.45	4.25	---	---	-2.245	0.189	---	48.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	Qg	ВНР	ВОС
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
31.08.2024	8513.07	7748.78	8399.25	7673.89	725.36	27.642	32.450	8282.0	1427.0
02.09.2024	8566.77	7798.71	8452.95	7723.34	729.61	25.397	32.639	8330.0	1427.0
Итого:	53.70	49.93	53.70	49.45	4.25	-2.245	0.189	48.0	0.0

Представитель абонента

Представитель энергоснабжающей организации