

Отчет о суточных параметрах  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Сигаева ул, д. 2 (МКД)

Прибор: ВКТ-7 Заводской номер: 00276301

Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (Схема 3)

Дата	t1	t2	dt	V1	V2	%	M1	M2	%	Mг	P1	P2	Qo	ВНР	ВОС	НС
	°C	°C	°C	м3	м3		т	т		т	кг/см2	кг/см2	Гкал	ч	ч	
01.09.2024	19.03	19.21	-0.18	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
02.09.2024	19.07	19.36	-0.29	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
03.09.2024	19.25	19.55	-0.30	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
04.09.2024	18.95	19.35	-0.40	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
05.09.2024	19.01	19.37	-0.36	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
06.09.2024	18.93	19.22	-0.29	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
07.09.2024	19.47	19.84	-0.37	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
08.09.2024	19.91	20.27	-0.36	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
09.09.2024	20.52	20.89	-0.37	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
10.09.2024	20.85	21.18	-0.33	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
11.09.2024	20.50	20.66	-0.16	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
12.09.2024	20.24	20.36	-0.12	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
13.09.2024	20.46	20.57	-0.11	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
14.09.2024	20.94	21.00	-0.06	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
15.09.2024	21.05	21.05	0.00	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
16.09.2024	21.27	21.25	0.02	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
17.09.2024	21.51	21.47	0.04	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
18.09.2024	21.55	21.55	0.00	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
19.09.2024	21.28	21.47	-0.19	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
20.09.2024	20.87	21.10	-0.23	0.00	0.00	---	0.00	0.00	---	0.00	6.00	5.00	0.000	24.0	0.0	*
21.09.2024	20.21	20.35	-0.14	0.02	0.00	200.00	0.02	0.00	200.00	0.02	6.00	5.00	0.000	24.0	0.0	*
22.09.2024	19.07	19.39	-0.32	0.40	2.20	-138.46	0.40	2.20	-138.46	-1.80	6.00	5.00	0.000	24.0	0.0	*
23.09.2024	39.39	20.35	19.04	23.53	24.63	-4.57	23.35	24.63	-5.34	-1.28	6.00	5.00	0.443	24.0	0.0	*
24.09.2024	53.96	25.10	28.86	66.67	65.56	1.68	65.78	65.44	0.52	0.34	6.00	5.00	1.895	24.0	0.0	
25.09.2024	62.49	42.73	19.76	238.49	236.12	1.00	234.23	234.01	0.09	0.22	6.00	5.00	4.632	24.0	0.0	
26.09.2024	65.38	47.59	17.79	420.66	415.91	1.14	412.49	411.48	0.25	1.01	6.00	5.00	7.335	24.0	0.0	
27.09.2024	64.47	47.41	17.06	413.06	408.01	1.23	405.27	403.69	0.39	1.58	6.00	5.00	6.911	24.0	0.0	
28.09.2024	64.39	47.24	17.15	409.57	405.53	0.99	401.84	401.24	0.15	0.60	6.00	5.00	6.891	24.0	0.0	
29.09.2024	64.22	46.68	17.54	376.85	372.87	1.06	369.77	369.04	0.20	0.73	6.00	5.00	6.484	24.0	0.0	
30.09.2024	61.76	44.64	17.12	235.08	231.57	1.50	230.95	229.39	0.68	1.56	6.00	5.00	3.951	24.0	0.0	*
Средние:	30.67	25.67	4.99	---	---	2.19	---	---	1.95	---	6.00	5.00	---	---	---	
Итого:	---	---	---	2184.33	2162.40	---	2144.10	2141.12	---	2.98	---	---	38.542	720.0	0.0	

Дата	V1	V2	M1	M2	Mг	Qo	ВНР	ВОС
	м3	м3	т	т	т	Гкал	ч	ч
31.08.2024	90113.29	91186.17	88094.18	89928.75	-1834.57	1798.363	10351.0	1323.0
30.09.2024	92297.62	93348.57	90238.28	92069.87	-1831.59	1836.905	11071.0	1323.0
Итого:	2184.33	2162.40	2144.10	2141.12	2.98	38.542	720.0	0.0

Представитель абонента

Представитель энергоснабжающей организации

Отчет о суточных параметрах ГВС  
(01.09.2024 0:00:00 - 30.09.2024 0:00:00)

Объект: Пермский край, Пермь г, Сигаева ул, д. 2 (МКД)

Прибор: ВКТ-7 Заводской номер: 00276301

Точка измерения: ТВ2; Ресурс: ГВС

Схема измерений: Открытая система отопления, ГВС с циркуляцией (Схема 3)

Дата	V1	V2	%	P1	P2	tхв	ВНР	ВОС	НС
	м3	м3		кг/см2	кг/см2	°C	ч	ч	
01.09.2024	225.19	196.21	13.75	5.00	4.00	5.00	0.0	24.0	*
02.09.2024	222.33	197.11	12.03	5.00	4.00	5.00	0.0	24.0	*
03.09.2024	---	---		---	---	---	---	---	
04.09.2024	---	---		---	---	---	---	---	
05.09.2024	---	---		---	---	---	---	---	
06.09.2024	---	---		---	---	---	---	---	
07.09.2024	---	---		---	---	---	---	---	
08.09.2024	---	---		---	---	---	---	---	
09.09.2024	---	---		---	---	---	---	---	
10.09.2024	---	---		---	---	---	---	---	
11.09.2024	---	---		---	---	---	---	---	
12.09.2024	---	---		---	---	---	---	---	
13.09.2024	---	---		---	---	---	---	---	
14.09.2024	---	---		---	---	---	---	---	
15.09.2024	---	---		---	---	---	---	---	
16.09.2024	---	---		---	---	---	---	---	
17.09.2024	---	---		---	---	---	---	---	
18.09.2024	---	---		---	---	---	---	---	
19.09.2024	---	---		---	---	---	---	---	
20.09.2024	---	---		---	---	---	---	---	
21.09.2024	---	---		---	---	---	---	---	
22.09.2024	---	---		---	---	---	---	---	
23.09.2024	---	---		---	---	---	---	---	
24.09.2024	---	---		---	---	---	---	---	
25.09.2024	---	---		---	---	---	---	---	
26.09.2024	---	---		---	---	---	---	---	
27.09.2024	---	---		---	---	---	---	---	
28.09.2024	---	---		---	---	---	---	---	
29.09.2024	---	---		---	---	---	---	---	
30.09.2024	---	---		---	---	---	---	---	
Средние:	---	---	12.89	5.00	4.00	5.00	---	---	
Итого:	447.52	393.32	---	---	---	---	0.0	48.0	

Дата	V1	V2	M1	M2	Mг	Qo	Qg	ВНР	ВОС
	м3	м3	т	т	т	Гкал	Гкал	ч	ч
31.08.2024	102067.16	89955.28	82547.31	72787.37	9759.94	1004.047	485.818	9007.0	2667.0
02.09.2024	102514.68	90348.60	82547.31	72787.37	9759.94	1004.047	485.818	9007.0	2715.0
Итого:	447.52	393.32	0.00	0.00	0.00	0.000	0.000	0.0	48.0

Представитель абонента

\_\_\_\_\_

Представитель энергоснабжающей организации

\_\_\_\_\_