

Отчет о суточных параметрах
(01.07.2026 0:00:00 - 31.07.2026 0:00:00)

Объект: Пермский край, Пермь г, Хрустальная ул, д. 30 (ООО УК "КОД")
Прибор: ТВ7 Заводской номер: 20137965
Точка измерения: ТВ1; Ресурс: ТС

Схема измерений: Закрытая система отопления (измерение расхода в двух трубопроводах) (Схема 6)

Дата	t1	t2	dt	V1	V2	M1	M2	%	dM	P1	P2	Qтв	ВНР	ВОС	tx	НС
	°C	°C	°C	м3	м3	т	т	т	т	кгс/см2	кгс/см2	ГКал	ч	ч	°C	
01.07.2026	19.81	19.37	0.44	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
02.07.2026	19.68	19.29	0.39	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
03.07.2026	19.64	19.21	0.42	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
04.07.2026	20.21	19.81	0.40	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
05.07.2026	20.33	19.96	0.37	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
06.07.2026	20.65	20.26	0.39	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
07.07.2026	20.92	20.55	0.37	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
08.07.2026	21.39	21.14	0.25	0.00	0.00	0.00	0.00	200.00	0.00	0.29	0.33	0.000	24.0	0.0	0.00	*
09.07.2026	21.00	20.58	0.42	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
10.07.2026	21.46	21.07	0.39	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
11.07.2026	21.38	21.08	0.30	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
12.07.2026	21.61	21.21	0.40	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
13.07.2026	21.30	20.90	0.40	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
14.07.2026	21.31	20.89	0.42	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
15.07.2026	21.11	20.69	0.41	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
16.07.2026	20.51	20.17	0.34	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
17.07.2026	20.34	19.98	0.37	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
18.07.2026	20.65	20.21	0.43	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
19.07.2026	20.88	20.48	0.40	0.00	0.00	0.00	0.00	---	0.00	0.04	0.12	0.000	24.0	0.0	0.00	
20.07.2026	21.19	20.79	0.40	0.00	0.00	0.00	0.00	---	0.00	0.11	0.23	0.000	24.0	0.0	0.00	
21.07.2026	21.31	21.01	0.30	0.00	0.00	0.00	0.00	---	0.00	3.70	3.82	0.000	24.0	0.0	0.00	
22.07.2026	21.63	21.31	0.32	0.00	0.00	0.00	0.00	---	0.00	8.12	8.03	0.000	24.0	0.0	0.00	
23.07.2026	21.63	21.38	0.26	0.00	0.00	0.00	0.00	---	0.00	10.40	10.06	0.000	24.0	0.0	0.00	
24.07.2026	22.17	21.86	0.32	0.00	0.00	0.00	0.00	---	0.00	9.94	9.63	0.000	24.0	0.0	0.00	
25.07.2026	22.56	22.24	0.32	0.00	0.00	0.00	0.00	---	0.00	9.58	9.27	0.000	24.0	0.0	0.00	
26.07.2026	22.95	22.63	0.32	0.00	0.00	0.00	0.00	---	0.00	9.27	9.00	0.000	24.0	0.0	0.00	
27.07.2026	23.29	22.97	0.32	0.00	0.00	0.00	0.00	---	0.00	8.99	8.79	0.000	24.0	0.0	0.00	
28.07.2026	23.53	23.20	0.33	0.00	0.00	0.00	0.00	---	0.00	8.71	8.63	0.000	24.0	0.0	0.00	
29.07.2026	23.40	23.10	0.31	0.00	0.00	0.00	0.00	-200.00	0.00	9.80	9.36	0.000	24.0	0.0	0.00	*
30.07.2026	23.20	22.86	0.34	0.00	0.00	0.00	0.00	---	0.00	10.29	9.79	0.000	24.0	0.0	0.00	
31.07.2026	22.81	22.46	0.34	0.00	0.00	0.00	0.00	---	0.00	9.71	9.52	0.000	24.0	0.0	0.00	
Средние:	21.41	21.05	0.36	---	---	---	---	0.00	---	3.22	3.18	---	---	---	0.00	
Итого:	---	---	---	0.00	0.00	0.00	0.00	---	0.00	---	---	0.000	744.0	0.0	---	

Дата	V1	V2	M1	M2	dM	Qтв	Q12	Qг	ВНР	ВОС
	м3	м3	т	т	т	ГКал	ГКал	ГКал	ч	ч
30.06.2026	363255.93	358513.14	355365.23	352417.40	2947.83	3514.188	0.000	0.000	32739.0	989.0
31.07.2026	363255.94	358513.14	355365.23	352417.40	2947.83	3514.188	0.000	0.000	33483.0	989.0
Итого:	0.00	0.00	0.00	0.00	0.00	0.000	0.000	0.000	744.0	0.0

Представитель абонента

Представитель энергоснабжающей организации